

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name LAUREL WOOD WATER USERS COOP PWS ID# 41 00315
 Month/Year 04/24 Entry Point: N SPRING Required Minimum Residual .2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00 A	Kitchen sink	0.95	
2	8:00 A		1.26	
3	9:00 A		1.33	
4	7:30 A		0.92	
5	8:30 A		0.76	
6	8:00 A		1.53	
7	8:00 A		0.83	
8	4:00 P		1.13	
9	8:00 A		1.65	
10	8:00 A		1.21	
11	2:00 P		1.01	
12	8:00 A		.81	
13	8:30 A		1.37	
14	7:30 A		1.41	
15	7:00 A		1.18	
16	7:30 A		1.23	
17	7:30 A		.98	
18	5:28 A		.93	
19	7:05 A		.79	
20	6:05 A		.72	
21	7:10 A		.74	
22	8:45 A		.74	
23	7:11 A		.76	
24	6:42 A		.98	BACTEST
25	7:13 A		.96	
26	7:49 A		.94	
27	7:54 A		.94	
28	7:07 A		1.06	
29	9:44 A		.86	
30	7:11 A		.98	
31				

Was the chlorine residual ever less than the required minimum residual of .2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____</p> <p>Date it was returned to service: _____</p>
--	--	---

Printed Name: JANE RUSSELL Title: _____ Operator Certification #: _____
 Signature: Jane Russell Phone #: (503) 703-7378
 Date: 04/30/24 OR
 Small Groundwater System