

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name LAURELWOOD WATER USERS COOP PWS ID# 41 00315
 Month/Year 7/25 Entry Point _____ Required Minimum Residual 12 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	6:46	KITCHEN SINK - FOR	.44	
2	7:13A	BAC. TEST	.43	
3	4:32p	Broom Tub	.48	
4	1:10p	B. Room Tub	.39	
5	4:24p	"	.42	
6	3:52p	"	.49	
7	6:45p	"	.54	
8	3:17p	"	.45	
9	5:04p	"	.44	
10	6:23p	"	.60	
11	2:32p	"	.42	
12	9:46A	"	.54	
13	5:25p	"	.47	
14	9:25a	"	.35	
15	4:42p	"	.27	
16	4:58p	"	.37	
17	7:14p	"	.27	
18	1:15p	"	.23	noticed water waste
19	3:20p	"	.33	
20	5pm	"	.18 / .32	let water run longer
21	6:07p	"	.27	
22	4:32p	"	.46	
23	8:26A	"	.83	
24	11:03A	"	.94	
25	7:38A	"	.80	
26	6:45A	"	.96	
27	7:06A	"	.94	BAC. TEST DONE
28	7:41	"	1.00	
29	11:20A	"	1.21	WATER TOO LOW TO BE ACCURATE - MAJOR
30	9:49 A	"	.42	LEAK (REPAIRED)
31	7:31A	"	.56	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? ☐ Yes ☐ No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____

Date it was returned to service: _____

Printed Name: TANE RUSSELL

Signature: Tane Russell

Date: 7/31/25

Title: _____

Phone #: () _____

Operator Certification #: _____

OR

Small Groundwater System ☐

December 19, 2012