

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name LAURELWOOD WATER USERS CO-OP

PWS ID# 41 00315

Month/Year FEB / 2024 Entry Point: NORTH SPRING

Required Minimum Residual 4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	5:56pm	BATH TUB	2.5	
2	6:05pm	"	1.6	
3	6:21pm	"	1.5	
4	6:15pm	"	1.3	
5	6:17pm	"	0.5	
6	4:40pm	Bath Tub	0.1	water master notified - Co-op members notified
7	11:08a	"	0.8	Tank dosed
8	11:45a	"	3.3	
9	1:52pm	"	3.9	
10	10:40a	"	4.7	
11	11:02a	"	4.0	Pump adjusted
12	4:08pm	"	3.9	
13	5:52pm	"	4.2	
14	5:26pm	"	4.0	
15	5:13pm	"	3.3	
16	5:31pm	"	4.2	
17	5:19pm	"	3.3	
18	5:02pm	"	2.7	
19	4:58pm	"	2.8	
20	4:59pm	"	2.7	
21	11:54am	"	3.4	
22	2:04pm	"	2.5	
23	3:27pm	"	2.4	
24	3:36pm	"	1.9	
25	4:08pm	"	2.5	
26	3:27pm	"	1.7	
27	4:18pm	"	2.0	
28	4:12pm	"	1.3	
29				
30				
31				

Air in the pipe. This was cleared.
 8:36pm: 0.4

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? 4 hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.4 mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Tammy BELTZ

Title:

Operator Certification #:

Signature: [Signature]

Phone #: (503) 608-0735

OR

Date: 02/02/2024

Small Groundwater System

Return by 10th of following month by either email dwp.dmce@odhsosha.oregon.gov; fax 971-673-0458; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.