State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name		ldaho Power- Oxbow Village		PWS ID# 4.1 00384				
EP-B, Entry Point for Month/Year June/2021 Entry Point: Copperfield Park Well Required Minimum Residual 0.2 mg/L								
Date	Time	Source(s) in use		Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes		
1	0700 Booster Pump			.52		House 5613 .36		
2	0700	Booster Pump		.43				
3	0700	Booster Pump		.42		House 851 .30		
4	0700	Booster Pump		.43				
5	0700	Booster Pump		.44				
6	0700	Booster Pump		.43				
7	0700	Booster Pump		.40		House 5620	.27	
8	0700	Booster Pump		.41				
9	0700	Booster Pump		.40				
10	0700	Booster Pump		.41		House 565 .	22	
11	0700	Booster Pump		.35				
12	0700	Booster Pump		.38				
13	0700	Booster Pump		.38				
14	0700	Booster Pump		.35		House 5613 .29		
15	0700	Booster Pump		.41				
16	0700	Booster Pump		.34				
17	0700	Booster Pump		.36		House 851 .26		
18	0700	Booster Pump		.29				
19	0700	Booster Pump		.28				
20	0700	Booster Pump		.26				
21	0700	Booster Pump		.24		House 5620 .16		
22	0700	Booster Pump		.21				
23	0700	Booster Pump		.22				
24	0700	Booster Pump		.24		House 565 .14		
25	0700	Booster Pump		.27				
26	0700	Booster Pump		.22				
27	0700	Booster Pump		.24		11 5040 40		
28	0700	Booster Pump		.23		House 5613 .13		
29	0700	Booster Pump		.23				
30	0700	Booster Pump		.23				
31		Booster Pump				<u> </u>		
Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☐ No								
If yes, what was the longest time period until the required level was restored?								
GW:	S Serving	3,300 or Fewer		GWS Serving More Than 3,300			00	
If yes, did you monitor every four hours until the residual returned to 0.2 mg/L? ☐ Yes ☐ No			Did continuous monitoring equipment fail at any time treporting month? Yes No			time this	Date continuous monitoring equipment failed:	
Attach those results and submit them with this form.			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?			Date it was returned to		
			Yes No Attach grab sample results and submit them with this fo			th this form.	service: / /	
Printed I	Name: Ha	with Phelps	Title: Bulling Madace tech Phone #: (541) 5407225		teca	Operator Certification #:		
Signatur	e: Mis	The	Phone #: (541) 5 407225		25	OR		
	07107					Small Gr	oundwater System	