State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Idaho Power- Oxbow Village PWS ID# 4 1 00384							
EP-B, Entry Point for Month/Year Feb/2022 Entry Point: Copperfield Park Well Required Minimum Residual 0.2 mg/L							
Date	Time Source		ı use	Lowest free chlorine residual at entry point distribution system (mg	to	Notes	
1	0700	Booster Pump		.43			
2	0700	Booster Pump		.43			
3	0700	Booster Pump		.43	House 5620	House 5620 .33	
4	0700	Booster Pump		.42			
5	0700	Booster Pump		.43			
6	0700	Booster Pump		.39			
7	0700	Booster Pump		.39	House 567	.31	
8	0700	Booster Pump		.40			
9	0700	Booster Pump		.40			
10	0700	Booster Pump		.30	House 5613	3 .25	
11	0700	Booster Pump		.28			
12	0700	Booster Pump		.37			
13	0700	Booster Pump		.40			
14	0700	Booster Pump		.40	House 851	.32	
15	0700	Booster Pump		.45			
16	0700	Booster Pump		.43			
17	0700	Booster Pump		.40	House 5620	.30	
18	0700	Booster Pump		.40			
19	0700	Booster Pump		.40			
20	0700	Booster Pump		.42			
21	0700	Booster Pump		.39	House 567	.25	
22	0700	Booster Pump		.38			
23	0700	Booster Pump		.42			
24	0700	Booster Pump		.44	House 5613	House 5613 .33	
25	0700	Booster Pump		.39			
26	0700	Booster Pump		.38			
27	0700	Booster Pump		.37			
28	0700	Booster Pump		.38	House 851	.29	
29		Booster Pump					
30		Booster Pump					
31		Booster Pump					
Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☐ No							
If yes, what was the longest time period until the required level was restored? hours							
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300							
If yes, did you monitor every four hours until the residual returned to 0.2 mg/L? ☐Yes ☐ No Attach those results and submit them with this form.			Did continuous monitoring equipment fail at any time this reporting month? Yes No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? Yes No		at any time this	Date continuous monitoring equipment failed:	
					Date it was returned to service:		
			Attach grab sample results and submit them w		m with this form.	1 1	
Printed Name: Heath Phelps Title: Building Maintenance Tec Operator Certification #:							
The state of the s							
-	11		Phone #: (541) 785-7225			OR	
Date: 03 / 01 / 2022					Small G	Small Groundwater System 🔲	