## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Idaho Power- Oxbow Village PWS ID# 4 1 00384						0384
EP-B, Entry Point for  Month/Year Sept/2023 Entry Point: Copperfield Park Well Required Minimum Residual 0.2 mg/L						
Date	Time	Source(s) in use		Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes	
1	1 0700 Booster Pump			.34		
2	0700	Booster Pump		.31		
3	0700	Booster Pump		.33		
4	0700	Booster Pump		.36		
5	0700	Booster Pump		.30	House 5620 .20	
6	0700	Booster Pump		.29		
7	0700	Booster Pump		.26	House 567 .18	
8	0700	Booster Pump		.28		
9	0700	Booster Pump		.31		
10	0700	Booster Pump		.33		
11	0700	Booster Pump		.34	House 5613 .22	
12	0700	Booster Pump		.36		
13	0700	Booster Pump		.32		
14	0700	Booster Pump		.32	House 851 .23	
15	0700	Booster Pump		.31		
16	0700	Booster Pump		.33		
17	0700	Booster Pump		.30		
18	0700	Booster Pump		.30	House 5620 .20	
19	0700	Booster Pump		.29		
20	0700	Booster Pump		.27		
21	0700	Booster Pump		.26	House 567 .17	
22	0700	Booster Pump		.26		
23	0700	Booster Pump		.24		
24	0700	Booster Pump		.28		
25	0700	Booster Pump		.29	House 5613 .19	
26	0700	Booster Pump		.27		
27	0700	Booster Pump		.26	0.5.4	00
28	0700	Booster Pump		.30	House 851 .20	
29	0700	Booster Pump		.34		
30	0700	Booster Pump		.33		
31 Booster Pump						
Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☐ No						
If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						800
If yes, did you monitor every four hours until the residual returned to 0.2 mg/L?  ☐Yes ☐ No  Attach those results and submit them with this form.			reporting month?  Yes  No			Date continuous monitoring equipment failed:
			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?   Yes No			Date it was returned to service:
			Attach grab sample results and submit them wit		with this form.	1 1
Printed	Name: Heat	n Phelps	Title: Building Maintenance tec		Operator Certification #:	
Signatú	re: 12		Phone #. (541) 785-7225		OR	
· <i>t</i> .						roundwater System 🔲