State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Idaha Dawar Oykaw Villaga						
System Name Idaho Power- Oxbow Village PWS ID# 4 1 00384 EP-B, Entry Point for						
Month/	Year Nov	1/2024 Entry Po		•	quired Minimum Residual 0.2 mg/L	
Date	Time	Source(s) in use		Lowest free chlorine residual at entry point to distribution system (mg/L	Notes	
1	0700	Booster Pump		.30		
2	0700	Booster Pump		.28		
3	0700	Booster Pump		.28		
4	0700	Booster Pump		.29	House 567	.18
5	0700	Booster Pump		.30		
6	0700	Booster Pump		.32		
7	0700	Booster Pump		.30	House 5613	3 .20
8	0700	Booster Pump		.32		
9	0700	Booster Pump		.30		
10	0700	Booster Pump		.33		
11	0700	Booster Pump		.33	House 851	.22
12	0700	Booster Pump		.34		
13	0700	Booster Pump		.33		
14	0700	Booster Pump		.34	House 5620	0 .22
15	0700	Booster Pump		.35		
16	0700	Booster Pump		.35		
17	0700	Booster Pump		.38		A-000
18	0700	Booster Pump		.36	House 567 .24	
19	0700	Booster Pump		.38		
20	0700	Booster Pump		.37		
21	0700	Booster Pump		.39	House 5613 .28	
22	0700	Booster Pump		.38		
23	0700	Booster Pump		.38		
24	0700	Booster Pump		.40		
25	0700	Booster Pump		.41	House 851 .30	
26	0700	Booster Pump		.39		
27	0700	Booster Pump		.42	House 5620 .30	
28	0700	Booster Pump		.40		
29	0700	Booster Pump		.41		
30	0700	Booster Pump		.40		
31		Booster Pump				
Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☒ No						
If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to 0.2 mg/L? ☐ Yes ☐ No Attach those results and submit them with this form.			Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No		any time this	Date continuous monitoring equipment failed:
			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? Yes No		Date it was returned to service:	
Attach grab sample results and submit them with this form.						
Printed Name: Heath Phelps			Title: Building Maintenance tec		Operator Certification #:	
Signature	e: 11/2	H.	Phone #: (541) 785-7225		OR	
	2 / 03 / 2024	V ?	-	,	Small Gr	roundwater System