State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Idaho Power- Oxbow Village PWS ID# 4 1 00384						
EP-B, Entry Point for Month/Year Dec/2024 Entry Point: Copperfield Park Well Required Minimum Residual 0.2 mg/L						ı Residual 0.2 mg/L
Date	Time	Source(s) in use		Lowest free chlorine residual at entry point to distribution system (mg/L)		
1	0700	Booster Pump		.46		
2	0700	Booster Pump		.45	House 567	.30
3	0700	Booster Pump		.46		
4	0700	Booster Pump		.42		
5	0700	Booster Pump		.43	House 5613	3 .31
6	0700	Booster Pump		.41		/////////////////////////////////////
7	0700	Booster Pump		.40		
8	0700	Booster Pump		.39		
9	0700	Booster Pump		.40	House 851	.28
10	0700	Booster Pump		.38		
11	0700	Booster Pump		.36		
12	0700	Booster Pump		.38	House 5620	0 .28
13	0700	Booster Pump		.37		
14	0700	Booster Pump		.37		
15	0700	Booster Pump		.36		
16	0700	Booster Pump		.39	House 567 .29	
17	0700	Booster Pump		.38		
18	0700	Booster Pump		.34		
19	0700	Booster Pump		.32	House 5613 .22	
20	0700	Booster Pump		.33		
21	0700	Booster Pump		.32		
22	0700	Booster Pump		.34		
23	0700	Booster Pump		.30	House 851 .20	
24	0700	Booster Pump		.31	House 5620 .22	
25	0700	Booster Pump		.29		
26	0700	Booster Pump		.30		
27	0700	Booster Pump		.28		
28	0700	Booster Pump		.26		
29	0700	Booster Pump	***************************************	.30		
30	0700	Booster Pump		.28	House 567	.19
31	0700	Booster Pump		.26		
Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☐ No						
If yes, what was the longest time period until the required level was restored? hours						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						300
If yes, did you monitor every four hours until the residual returned to 0.2 mg/L?				monitoring equipment fail at ar		Date continuous monitoring equipment failed:
□Yes □ No			If yes, were grab samples collected every four hours until the			
Attach	those results	and submit them with	continuous monitoring equipment was returned to service? Date it was returned to			
this form.			☐ Yes ☐ No service:			service:
			Attach grab sar	Attach grab sample results and submit them with this form. / /		
Printed N	Name: Heath	Phelps	Title: Building Maintenance Tec		Operator Certification #:	
Signatur	e: 4/4		Pho	one #: (541) 785-7225		OR
Date: 01	1 / 07 / 2025				Small G	roundwater System