

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Independence

PWS ID# 41 00399

Month/Year 11 / 24 Entry Point: EP-B

Required Minimum Residual 0.2 mg/L

| Date | Time | Source(s) in use | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes |
|------|------------|------------------|--|-------|
| 1 | 11:33pm | All source water | .75 mg/L | MC |
| 2 | 7:40am | " | .75 mg/L | MC |
| 3 | 9:00am | " " | .73 mg/L | NR |
| 4 | 5:43am | " " | .36 mg/L | SH |
| 5 | 5:53am | " " | .53 mg/L | SH |
| 6 | 5:58am | " " | .53 mg/L | SH |
| 7 | 5:45am | " " | .51 mg/L | SH |
| 8 | 8:50am | " " | .68 mg/L | JR |
| 9 | 8:53am | " " | .61 mg/L | JR |
| 10 | 8:34am | " " | .70 mg/L | JR |
| 11 | 11:00pm | " " | .55 mg/L | NR |
| 12 | 12:42 A.M. | " " | .56 mg/L | CT |
| 13 | 6:57pm | " " | .52 mg/L | HR |
| 14 | 5:55am | " " | .61 mg/L | NR |
| 15 | 7:20am | " " | .52 mg/L | NR |
| 16 | 7:16am | " " | .61 mg/L | SH |
| 17 | 7:20am | " " | .52 mg/L | SH |
| 18 | 5:55am | " " | .59 mg/L | SH |
| 19 | 11:01 P.M. | " " | .48 mg/L | CT |
| 20 | 6:14 P.M. | " " | .48 mg/L | CT |
| 21 | 3:06 P.M. | " " | .65 mg/L | CT |
| 22 | 11:34 P.M. | " " | .57 mg/L | CT |
| 23 | 10:32 A.M. | " " | .57 mg/L | CT |
| 24 | 7:26 A.M. | " " | .48 mg/L | CT |
| 25 | 5:00 P.M. | " " | .54 mg/L | CT |
| 26 | 11:20AM | " " | .54 mg/L | NE |
| 27 | 6:19 A.M. | " " | .46 mg/L | CT |
| 28 | 7:33AM | " " | .46 mg/L | NE |
| 29 | 11:35PM | " " | .43 mg/L | NE |
| 30 | 7:49AM | " " | .47 mg/L | NE |
| 31 | | | | |

Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No
 If yes, what was the longest time period until the required level was restored? hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No


Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Matthew Carpenter Title: WATER DRC
 Signature:  Phone #: (503) 932-6204
 Date: 11 / 2 / 2024

Operator Certification #: 6621
 OR
 Small Groundwater System ☐

Return by 10th of following month by either email dwp.dmc@dhsoha.state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.