

System Name CITY OF LAFAYETTE

PWS ID# 41-C0452

Month/Year NOV/2020 Entry Point - A

Required Minimum Residual 2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1 AM	W10, W3, PS, LS, BBS	.90	
2	1 AM	W10, W3, PS, LS, BBS	.90	
3	12 AM	W10, W3, PS, LS, BBS	1.05	
4	3 AM	W10, W3, PS, LS, BBS	1.12	
5	2 AM	W10, W3, PS, LS, BBS	1.12	
6	2 AM	W10, W3, PS, LS, BBS	1.08	
7	1 AM	W10, W3, PS, LS, BBS	1.14	
8	11 PM	W10, W3, PS, LS, BBS	.95	
9	12 AM	W10, W3, PS, LS, BBS	.90	
10	1 AM	W10, W3, PS, LS, BBS	.85	
11	12 AM	W10, W3, PS, LS, BBS	.95	
12	2 AM	W10, W3, PS, LS, BBS	1.00	
13	2 AM	W10, W3, PS, LS, BBS	1.00	
14	1 AM	W10, W3, PS, LS, BBS	1.00	
15	1 AM	W10, W3, PS, LS, BBS	1.03	
16	2 AM	W10, W3, PS, LS, BBS	1.12	
17	1 AM	W10, W3, PS, LS, BBS	1.00	
18	11 PM	W10, W3, PS, LS, BBS	.95	
19	12 AM	W10, W3, PS, LS, BBS	.95	
20	12 AM	W10, W3, PS, LS, BBS	.85	
21	10 PM	W10, W3, PS, LS, BBS	.87	
22	11 PM	W10, W3, PS, LS, BBS	.85	
23	12 AM	W10, W3, PS, LS, BBS	.80	
24	12 AM	W10, W3, PS, LS, BBS	1.00	
25	1 AM	W10, W3, PS, LS, BBS	1.15	
26	1 AM	W10, W3, PS, LS, BBS	1.10	
27	11 PM	W10, W3, PS, LS, BBS	1.00	
28	12 AM	W10, W3, PS, LS, BBS	.95	
29	12 AM	W10, W3, PS, LS, BBS	.95	
30	11 PM	W10, W3, PS, LS, BBS	.90	
31		W10, W3, PS, LS, BBS		

Was the chlorine residual ever less than the required minimum residual of + 2 mg/L?  Yes  No

If yes, what was the longest time period until the required level was restored? hours - If &gt; 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**If yes, did you monitor every four hours until the residual returned to mg/L as required?  Yes  No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**Did continuous monitoring equipment fail at any time this reporting month?  Yes  NoIf yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ / A

Date it was returned to service:

/ /

Printed Name: Greg D. Robinson

Title: PW Supervisor

Operator Certification #: 09140

Signature: Greg D. Robinson

Phone #: (503) 437-0421

OR

Date: 12/01/2020

Small Groundwater System 

December 19, 2012