

System Name City of Lafayette

PWS ID# 41-00452

Month/Year Nov. / 2003 Entry Point: - A

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	12am	W10, W8, PS, LS, BBS	.70	
2	12am	W10, W8, PS, LS, BBS	.70	
3	1am	W10, W8, PS, LS, BBS	.65	
4	1am	W10, W8, PS, LS, BBS	.50	
5	12am	W10, W8, PS, LS, BBS	.60	
6	11pm	W10, W8, PS, LS, BBS	.60	
7	12am	W10, W8, PS, LS, BBS	.70	
8	2am	W10, W8, PS, LS, BBS	.65	
9	1am	W10, W8, PS, LS, BBS	.70	
10	12am	W10, W8, PS, LS, BBS	.75	
11	12am	W10, W8, PS, LS, BBS	.80	
12	1am	W10, W8, PS, LS, BBS	.70	
13	1am	W10, W8, PS, LS, BBS	.75	
14	2am	W10, W8, PS, LS, BBS	.70	
15	12am	W10, W8, PS, LS, BBS	.70	
16	1am	W10, W8, PS, LS, BBS	.85	
17	12am	W10, W8, PS, LS, BBS	.90	
18	2am	W10, W8, PS, LS, BBS	.95	
19	1am	W10, W8, PS, LS, BBS	.95	
20	1am	W10, W8, PS, LS, BBS	.90	
21	2am	W10, W8, PS, LS, BBS	.95	
22	11pm	W10, W8, PS, LS, BBS	.95	
23	12am	W10, W8, PS, LS, BBS	.60	
24	12am	W10, W8, PS, LS, BBS	.50	
25	12am	W10, W8, PS, LS, BBS	.60	
26	1am	W10, W8, PS, LS, BBS	.70	
27	12am	W10, W8, PS, LS, BBS	.70	
28	12am	W10, W8, PS, LS, BBS	.70	
29	12am	W10, W8, PS, LS, BBS	.90	
30	12am	W10, W8, PS, LS, BBS	.95	
31	—	W10, W8, PS, LS, BBS	—	

Was the chlorine residual ever less than the required minimum residual of .2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed: <u>11/1/03</u></p> <p>Date it was returned to service: <u>11/1/03</u></p>	

Printed Name: Gregg Robinson
 Signature: [Signature]
 Date: 11/06/2003

Title: PW Supervisor
 Phone #: (503) 437-0401

Operator Certification # 09140
 OR
 Small Groundwater System