

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Flying K Trailer Ranch PWS ID# 4 1 00455
 Month/Year 7/21 Entry Point: EP-B for wells #2 & #3 Required Minimum Residual 0.4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16	9:00	#2 & 3	0.4	
17	10:00	#2 & 3	0.8	
18	10:00	#2 + 3	0.6	
19	11:00	#2 + 3	0.6	
20	10:00	#2 + 3	0.4	
21	10:00	#2 + 3	0.6	
22	11:30	#2 + 3	0.6	
23	10:00	#2 + 3	0.6	
24	9:30	#2 + 3	0.6	
25	10:00	#2 + 3	0.4	
26	10:15	#2 + 3	0.6	
27	11:00	#2 + 3	0.6	
28	2:00	#2 + 3	0.6	
29	11:30	#2 + 3	0.6	
30	1:30	#2 + 3	0.6	
31	10:30	#2 + 3	0.6	

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.4 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
--	--

Printed Name: Randy Chandler Title: caretaker
 Signature: [Signature] Phone #: (541) 910-3676
 Date: 8/2/2021
 Operator Certification #: 41-00455
 OR
 Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019