

State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Flying K Trailer Ranch PWS ID# 41 00455
 Month/Year 12/2022 Entry Point: EP-B for wells #2 & #3 Required Minimum Residual 0.4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:10	wells 2 & 3	.6	
2	12:30		.6	
3	11:20		.6	
4	4:10		.6	
5	12:30		.6	
6	9:35		.6	
7	11:40		.6	
8	11:45		.6	
9	2:45		.6	
10	12:00		.6	
11	2:30		.6	
12	10:30		.6	
13	12:25		.6	
14	12:00		.6	
15	11:30		1.0	
16	9:25		1.0	
17	10:00		.8	
18	12:15		.8	
19	10:45		.8	
20	3:30		.8	
21	10:45		.8	
22	10:45		.6	
23	12:45		.6	
24	11:00		.6	
25	12:30		.6	
26	1:00		.6	
27	9:45		.6	
28	9:50		.6	
29	1:15		.6	
30	11:30		.6	
31	11:00		.6	

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.4 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
--	--

Printed Name: Joni Chandler Title: Contractor Operator Certification #: _____
 Signature: Joni Chandler Phone #: (541) 786-5465 OR
 Date: 12/13/2022 Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.