

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Flying K Trailer Ranch

PWS ID# 41 00455

Month/Year 7 / 2023 Entry Point: EP-B for wells #2 & #3

Required Minimum Residual 0.4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	11:15	well 2 + 3	.8	
2	11:50		.8	
3	11:30		.8	
4	10:05		.8	
5	12:30		.8	
6	10:30		.8	
7	11:00		.8	
8	10:50		.8	
9	12:40		.8	
10	11:05		.8	
11	11:00		.8	
12	9:35		.8	
13	9:25		.8	
14	9:00		.8	
15	9:55		.8	
16	9:30		.8	
17	8:45		.6	
18	9:35		.6	
19	11:00		.6	
20	9:00		.6	
21	9:45		.6	
22	7:30		.6	
23	8:45		.6	
24	10:45		.6	
25	9:30		.6	
26	1:00		.6	
27	8:15		.6	
28	9:40		.8	
29	10:00		.8	
30	9:10		.8	
31	8:30		.8	

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.4 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
--	--

Printed Name: Joni Chandler Title: operator Operator Certification #: _____
 Signature: Joni Chandler Phone #: (541) 786-5403 OR
 Date: 7 / 31 / 2023 Small Groundwater System

Return by 10th of following month by either email dwp.dnce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.