

Monthly Disinfection Report for Ground Water Systems

System Name City of Lostine PWS ID# 4.1 00491
 -Month/Year 4/22/11 Entry Point: EP-A for Springs Required Minimum Residual 0.3 mg/L

Date	Time	Source(s) In use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1		SPRINGS	0.45	
2			0.44	
3			0.41	
4			0.42	
5			0.52	
6			0.48	
7			0.42	
8			0.38	
9			0.41	
10			0.43	
11			0.37	
12			0.39	
13			0.39	
14			0.42	
15			0.38	
16			0.43	
17			0.45	
18			0.37	
19			0.40	
20			0.39	
21			0.42	
22			0.42	
23			0.47	
24			0.44	
25			0.40	
26			0.39	
27			0.38	
28			0.39	
29			0.41	
30			0.37	
31				

Was the chlorine residual ever less than the required minimum residual of 0.30 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to ___ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
--	---

Printed Name: Shawn Young Title: WATER MASTER Operator Certification #: D-6739
 Signature: Shawn Young Phone #: (541) 569 2415
 Date: 5.4.22/11

OR
Small Groundwater System