

Monthly Disinfection Report for Ground Water Systems

System Name City of Lostine PWS ID# 4.1 00491
 Month/Year Dec / 2023 Entry Point: EP-A for Springs Required Minimum Residual 0.3 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1		SPRINGS	0.64	
2			0.68	
3			0.76	
4			0.73	
5			0.70	
6			0.71	
7			0.74	
8			0.69	
9			0.60	
10			0.63	
11			0.68	
12			0.75	
13			0.72	
14			0.74	
15			0.71	
16			0.67	
17			0.65	
18			0.65	
19			0.63	
20			0.71	
21			0.67	
22			0.64	
23			0.70	
24			0.66	
25			0.63	
26			0.62	
27			0.57	
28			0.55	
29			0.63	
30			0.64	
31			0.64	

Was the chlorine residual ever less than the required minimum residual of 0.30 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
--	--

Printed Name: Shawn Young Title: WATER MASTER Operator Certification #: D-6739
 Signature: [Signature] Phone #: (541) 569 2415
 Date: 1.10.2024

OR
 Small Groundwater System