

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name **Neahkahnie Water District**

PWS ID# **4 1 00506**

Month/Year **Dec. 1 2021** Entry Point: **WTP-B (Hyd.#66)**

Required Minimum Residual **0.4 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1		<i>spr's 1-3 + Pirates spr</i>	<i>0.53</i>	
2			<i>0.62</i>	
3			<i>0.61</i>	
4			<i>0.54</i>	
5			<i>0.55</i>	
6			<i>0.46</i>	
7			<i>0.42</i>	
8			<i>0.43</i>	
9			<i>0.48</i>	
10			<i>0.42</i>	
11			<i>0.43</i>	
12			<i>0.40</i>	
13			<i>0.42</i>	
14			<i>0.41</i>	
15			<i>0.41</i>	
16			<i>0.41</i>	
17			<i>0.55</i>	
18			<i>0.58</i>	
19			<i>0.52</i>	
20			<i>0.60</i>	
21			<i>0.56</i>	
22			<i>0.48</i>	
23			<i>0.56</i>	
24			<i>0.55</i>	
25			<i>0.60</i>	
26			<i>0.59</i>	
27			<i>0.58</i>	
28			<i>0.58</i>	
29			<i>0.60</i>	
30			<i>0.55</i>	
31			<i>0.55</i>	

Was the chlorine residual ever less than the required minimum residual of **0.40** mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: *Spott A Morrill* Title: *DRE / System OP* Operator Certification #: *T-9278*  
 Signature: *Spott A Morrill* Phone #: *(503) 804.4649* OR *D-9279*  
 Date: *12/31/2021* Small Groundwater System