

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name **Neahkahnie Water District**

PWS ID# **4 1 00506**

Month/Year **04 12022** Entry Point: **WTP-B (Hyd.#66)**

Required Minimum Residual **0.4 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1		Spr's 1-3 & Pirates Spr.	0.41	
2			0.48	
3			0.51	
4			0.52	
5			0.49	
6			0.49	
7			0.48	
8			0.49	
9			0.50	
10			0.64	
11			0.69	
12			0.68	
13			0.65	
14			0.54	
15			0.51	
16			0.57	
17			0.49	
18			0.55	
19			0.51	
20			0.49	
21			0.48	
22			0.50	
23			0.54	
24			0.51	
25			0.52	
26			0.47	
27			0.50	
28			0.50	
29			0.57	
30			0.57	
31				

Was the chlorine residual ever less than the required minimum residual of **0.40** mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: <u>Scott A. Merrill</u> Signature: <u>Scott A. Merrill</u> Date: <u>05/02/2022</u>	Title: <u>DRE System Operator</u> Phone #: <u>(503) 804-4649</u>	Operator Certification #: <u>T-9278</u> <u>D-9279</u> OR Small Groundwater System <input type="checkbox"/>
--	---	---