

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Neahkahnie Water District

PWS ID# 4 1 00506

Month/Year 04 / 2023 Entry Point: WTP-B (Hyd. #66)

Required Minimum Residual 0.4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1		<i>Spr's 1-3 + Pirates spr.</i>	0.52	
2			0.63	
3			0.54	
4			0.56	
5			0.54	
6			0.51	
7			0.54	
8			0.52	
9			0.50	
10			0.52	
11			0.52	
12			0.54	
13			0.54	
14			0.56	
15			0.57	
16			0.56	
17			0.56	
18			0.55	
19			0.53	
20			0.56	
21			0.53	
22			0.53	
23			0.53	
24			0.53	
25			0.53	
26			0.50	
27			0.50	
28			0.49	
29			0.50	
30			0.53	
31				

Was the chlorine residual ever less than the required minimum residual of 0.40 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: <u>Scott Morrill</u> Signature: <u>Scott A Morrill</u> Date: <u>04/30/2023</u>	Title: <u>System Operator DRC</u> Phone #: <u>(503) 804.4649</u>	Operator Certification #: <u>T-09278</u> <u>D-09279</u> OR Small Groundwater System <input type="checkbox"/>
--	---	---