## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Neahkahnie Water District					PWS ID# 4 1 00506		
Month/Y	ear <i>05</i>	12022 Entry F	Point: WTP-B	(Hyd.#66)	Required Minimu	m Residual 0.4 mg/L	
Date	Time	Source(s	in use	Lowest free chloring residual at entry point distribution system (mg	to	Notes	
1		Spr. 51-3 + Pirat	les Spr.	0,50			
2				0.49			
3				0.51			
5				0.52			
6				0,48			
7			and and the second	0.44			
8	***************************************			0.47			
9				0,49			
10				0.51			
11			akundi di kini kini mila suka di kini dikumbi milikumbi, wa kasa ya ya di kasa ya ya di kini di kini di kini d	0.48			
12				0.46			
13				0.46			
14				0.58			
15				0.49			
16				0.42			
17		<del></del>		0.44			
18				0.40			
20				0.47			
21		<u> </u>		0.48			
22				051			
23				0.51 p.52			
24				0.57			
25				0.55			
26				0.58			
27				0.56			
28				0.53			
29				0.51			
30				0.49			
31		<u> </u>		0.54			
				, -	Yes No		
If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.							
GWS Serving 3,300 or Fewer				GWS Serving More Than 3,300			
If yes, did you monitor every four hours until the residual returned to mg/L			Did continuous monitoring equipment fail at any time this reporting month?  Yes No		Date continuous monitoring equipment failed:		
as required? Yes No			If yes, were grab samples collected every for		ur hours until the	1 1	
Attach those results and submit them with this form.			continuous monitoring equipment was return required? Yes No			Date it was returned to service:	
			Attach grab sample results and submit them		with this form.	1 1	
3				System OP/DRC	Operator	r Certification #: $7-29278$	
Signature:_	Secti	& Maielf	? Phon	e#:(503)804.4649	0	OR D-09279	
Date: 05	ate: 05   31   Z0ZZ Small Groundwater System						