

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City of Maupin

Springs Pump House

PWS ID# 41 00510

Month/Year Mar/2023 Entry Point:

Required Minimum Residual 0.30 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:56	S/S 1/2/3	0.49	
2	8:57		0.49	
3	7:25		0.55	
4	9:47		0.50	
5	11:25		0.44	
6	7:34		0.55	
7	7:34		0.41	Running
8	7:19		0.50	
9	7:32		0.52	
10	7:02		0.55	
11	9:00		0.53	
12	10:43		0.64	
13	8:43		0.56	
14	8:15		0.53	
15	7:16		0.52	
16	7:18		0.52	
17	7:38		0.48	
18	8:47		0.50	
19	9:41		0.52	
20	7:25		0.50	
21	7:23		0.50	
22	7:32		0.50	
23	7:33		0.50	
24	7:35		0.45	Running
25	10:52		0.41	Running
26	10:54		0.45	
27	7:26		0.47	
28	7:40		0.52	
29	7:54		0.48	
30	7:47		0.54	
31	8:07		0.40	Running
			0.48	

Was the chlorine residual ever less than the required minimum residual of mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to mg/L as required?  Yes  No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

1 1  
Date it was returned to service:

1 1

Printed Name: Kirk Shields

Signature: *K. Shields*

Date: 4/6/23

Title: Foreman

Phone #: (541) 395-2684

Operator Certification #:

OR D-09131

Small Groundwater System

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name **City of Maupin** **Water Ave** PWS ID# **41 00510**  
 Month/Year **Mar/2023** Entry Point **Lower Res.** Required Minimum Residual **0.30 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:45	SB 1/2/3	0.55	
2	8:42		0.36	
3	7:08		0.51	
4	11:30		0.38	
5	11:09		0.48	
6	7:17		0.52	
7	7:13		0.41	
8	7:03		0.55	
9	7:15		0.39	
10	6:48		0.53	
11	8:43		0.48	
12	10:29		0.56	
13	8:33		0.51	
14	8:22		0.43	
15	7:01		0.50	
16	6:52		0.39	
17	7:21		0.51	
18	8:39		0.38	
19	9:57		0.52	
20	7:09		0.40	
21	7:07		0.37	
22	7:11		0.43	
23	7:17		0.42	
24	7:15		0.51	
25	12:48		0.43	
26	11:47		0.49	
27	7:06		0.42	
28	7:22		0.38	
29	7:36		0.50	
30	7:31		0.39	
31	7:45		0.49	

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed: _____ / _____ / _____</p> <p>Date it was returned to service: _____ / _____ / _____</p>	

Printed Name: **Kirk Shields** Title: **Foreman** Operator Certification #: \_\_\_\_\_  
 Signature: *K Shields* Phone #: **(541) 395-2684** OR **D-09131**  
 Date: **4/6/23** Small Groundwater System

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City of Maupin

*East Maupin*

PWS ID# 41 00510

Month/Year *May 2023* Entry Point:

Required Minimum Residual *0.30* mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:10	<i>SB 1-2-3</i>	<i>0.42</i>	
2	9:44		<i>0.49</i>	
3	8:05		<i>0.43</i>	
4	10:15		<i>0.38</i>	
5	11:50		<i>0.42</i>	
6	8:00		<i>0.41</i>	
7	7:55		<i>0.44</i>	
8	7:57		<i>0.44</i>	
9	7:53		<i>0.42</i>	
10	9:30		<i>0.44</i>	
11	10:55		<i>0.43</i>	
12	8:50		<i>0.41</i>	
13	8:30		<i>0.44</i>	
14	7:42		<i>0.42</i>	
15	7:45		<i>0.41</i>	
16	8:10		<i>0.43</i>	
17	8:12		<i>0.43</i>	
18	8:30		<i>0.40</i>	
19	9:30		<i>0.42</i>	
20	7:53		<i>0.41</i>	
21	7:50		<i>0.43</i>	
22	7:53		<i>0.46</i>	
23	7:56		<i>0.47</i>	
24	8:03		<i>0.40</i>	
25	10:45		<i>0.43</i>	
26	10:45		<i>0.40</i>	
27	7:53		<i>0.40</i>	
28	8:20		<i>0.40</i>	
29	8:20		<i>0.37</i>	
30	8:09		<i>0.38</i>	
31	8:48		<i>0.39</i>	

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____ / _____ / _____</p> <p>Date it was returned to service: _____ / _____ / _____</p>
--	--	---

Printed Name: *Mark Shields* Title: *Foreman*  
 Signature: *[Signature]* Phone #: *541 395-2698*  
 Date: *4/16/23*

Operator Certification #: *OR 17-09131*  
 Small Groundwater System