



	A	B	C	D
1	State of Oregon Drinking Water Program			
2	Monthly Disinfection Report for Groundwater System			
3	System Name: Medford Water Commission			
4	Month/Year:	Nov, 2021	Entry Point: EP-A, Big Butte Springs	
5	Date	Time	Source(s) in use	Lowest free Chlorine residual at entry point to distribution system (mg/L)
6	11/01/21	11/01/2021 12:00 am	Big Butte Springs	0.56
7	11/02/21	11/02/2021 12:00 am	Big Butte Springs	0.56
8	11/03/21	11/03/2021 05:00 am	Big Butte Springs	0.55
9	11/04/21	11/04/2021 12:00 am	Big Butte Springs	0.56
10	11/05/21	11/05/2021 02:00 am	Big Butte Springs	0.55
11	11/06/21	11/06/2021 12:00 am	Big Butte Springs	0.55
12	11/07/21	11/07/2021 05:00 am	Big Butte Springs	0.54
13	11/08/21	11/08/2021 10:00 am	Big Butte Springs	0.54
14	11/09/21	11/09/2021 04:00 am	Big Butte Springs	0.54
15	11/10/21	11/10/2021 12:00 am	Big Butte Springs	0.54
16	11/11/21	11/11/2021 12:00 am	Big Butte Springs	0.55
17	11/12/21	11/12/2021 03:00 am	Big Butte Springs	0.55
18	11/13/21	11/13/2021 12:00 am	Big Butte Springs	0.56
19	11/14/21	11/14/2021 03:00 am	Big Butte Springs	0.56
20	11/15/21	11/15/2021 12:00 am	Big Butte Springs	0.56
21	11/16/21	11/16/2021 12:00 am	Big Butte Springs	0.57
22	11/17/21	11/17/2021 12:00 am	Big Butte Springs	0.57
23	11/18/21	11/18/2021 12:00 am	Big Butte Springs	0.57
24	11/19/21	11/19/2021 12:00 am	Big Butte Springs	0.57
25	11/20/21	11/20/2021 12:00 am	Big Butte Springs	0.57
26	11/21/21	11/21/2021 12:00 am	Big Butte Springs	0.57
27	11/22/21	11/22/2021 06:00 am	Big Butte Springs	0.57
28	11/23/21	11/23/2021 12:00 am	Big Butte Springs	0.57
29	11/24/21	11/24/2021 11:00 am	Big Butte Springs	0.58
30	11/25/21	11/25/2021 12:00 am	Big Butte Springs	0.58
31	11/26/21	11/26/2021 12:00 am	Big Butte Springs	0.58
32	11/27/21	11/27/2021 12:00 am	Big Butte Springs	0.58
33	11/28/21	11/28/2021 12:00 am	Big Butte Springs	0.58
34	11/29/21	11/29/2021 06:00 am	Big Butte Springs	0.57
35	11/30/21	11/30/2021 06:00 am	Big Butte Springs	0.57
36			Big Butte Springs	
37	Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> NO			
38	If yes, what was the longest time period until the required level was restored? _____ Hours			
39	GWS Serving 3,300 or Fewer		GWS Serving More Than 3,300	
40	If yes, did you monitor every four hours until the residual returned to _____ mg/L?		Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
41				
42			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?	
43			<input type="checkbox"/> YES <input type="checkbox"/> NO	
44	<i>Attach those results and submit them</i>			
45			<i>Attach grab sample results and submit them with this form.</i>	
46	Printed Name: Dan Perkins			Title: Plant Supervisor
47	Signature: 			Phone #: (541) 774-2434
48	Date:	12/1/2021		