


	A	B	C	D	E
1	State of Oregon Drinking Water Program				
2	Monthly Disinfection Report for Groundwater Systems				
3	System Name: Medford Water Commission			PWS ID#: OR 41-00513	
4	Month/Year:	Jan, 2022	Entry Point: EP-A, Big Butte Springs	Required Minimum Residual: 0.25 mg/L	
5	Date	Time	Source(s) in use	Lowest free Chlorine residual at entry point to distribution system (mg/L)	Notes
6	01/01/22	01/01/2022 12:00 am	Big Butte Springs	0.56	
7	01/02/22	01/02/2022 12:00 am	Big Butte Springs	0.56	
8	01/03/22	01/03/2022 03:00 pm	Big Butte Springs	0.40	
9	01/04/22	01/04/2022 06:00 am	Big Butte Springs	0.54	
10	01/05/22	01/05/2022 01:00 pm	Big Butte Springs	0.55	
11	01/06/22	01/06/2022 07:00 am	Big Butte Springs	0.54	
12	01/07/22	01/07/2022 11:00 pm	Big Butte Springs	0.52	
13	01/08/22	01/08/2022 12:00 am	Big Butte Springs	0.52	
14	01/09/22	01/09/2022 02:00 am	Big Butte Springs	0.52	
15	01/10/22	01/10/2022 12:00 am	Big Butte Springs	0.52	
16	01/11/22	01/11/2022 09:00 am	Big Butte Springs	0.51	
17	01/12/22	01/12/2022 12:00 am	Big Butte Springs	0.51	
18	01/13/22	01/13/2022 12:00 am	Big Butte Springs	0.51	
19	01/14/22	01/14/2022 12:00 am	Big Butte Springs	0.51	
20	01/15/22	01/15/2022 12:00 am	Big Butte Springs	0.51	
21	01/16/22	01/16/2022 12:00 am	Big Butte Springs	0.51	
22	01/17/22	01/17/2022 05:00 pm	Big Butte Springs	0.50	
23	01/18/22	01/18/2022 12:00 am	Big Butte Springs	0.50	
24	01/19/22	01/19/2022 12:00 am	Big Butte Springs	0.50	
25	01/20/22	01/20/2022 12:00 am	Big Butte Springs	0.50	
26	01/21/22	01/21/2022 12:00 am	Big Butte Springs	0.50	
27	01/22/22	01/22/2022 12:00 am	Big Butte Springs	0.50	
28	01/23/22	01/23/2022 09:00 am	Big Butte Springs	0.50	
29	01/24/22	01/24/2022 12:00 am	Big Butte Springs	0.50	
30	01/25/22	01/25/2022 12:00 am	Big Butte Springs	0.51	
31	01/26/22	01/26/2022 12:00 pm	Big Butte Springs	0.50	Equipment maintenance 1223 to 1312 hrs
32	01/27/22	01/27/2022 12:00 am	Big Butte Springs	0.53	
33	01/28/22	01/28/2022 06:00 am	Big Butte Springs	0.52	
34	01/29/22	01/29/2022 03:00 am	Big Butte Springs	0.53	
35	01/30/22	01/30/2022 12:00 am	Big Butte Springs	0.53	
36	01/31/22	01/31/2022 12:00 am	Big Butte Springs	0.53	
37	Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> NO				
38	If yes, what was the longest time period until the required level was restored? _____ Hours				
39	GWS Serving 3,300 or Fewer		GWS Serving More Than 3,300		
40	If yes, did you monitor every four hours until the residual returned to _____ mg/L?		Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		Date continuous monitoring equipment failed: / /
41	Attach those results and submit them		If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO		Date it was returned to service: / /
42			Attach grab sample results and submit them with this form.		/ /
43					
44	Printed Name: Dan Perkins		Title: Plant Supervisor		Operator Certification #: 2339
45	Signature: 		Phone #: (541) 774-2434		OR
46	Date:	2/2/2022			Small Groundwater System _____