

State of Oregon Drinking Water Program
Monthly Disinfection Report for Groundwater Systems

System Name: Medford Water Commission

PWS ID#: OR 41-00513

Month/Year: **Jul, 2022**


Entry Point: EP-A, Big Butte Springs

Required Minimum Residual: 0.25 mg/L

Date	Time	Source(s) in use	Lowest free Chlorine residual at entry point to distribution system (mg/L)	Notes
07/01/22	07/01/2022 04:00 am	Big Butte Springs	0.56	
07/02/22	07/02/2022 12:00 am	Big Butte Springs	0.56	
07/03/22	07/03/2022 01:00 am	Big Butte Springs	0.55	
07/04/22	07/04/2022 08:00 pm	Big Butte Springs	0.55	
07/05/22	07/05/2022 12:00 am	Big Butte Springs	0.55	
07/06/22	07/06/2022 02:00 pm	Big Butte Springs	0.55	
07/07/22	07/07/2022 12:00 am	Big Butte Springs	0.55	
07/08/22	07/08/2022 01:00 am	Big Butte Springs	0.55	
07/09/22	07/09/2022 03:00 am	Big Butte Springs	0.54	
07/10/22	07/10/2022 04:00 am	Big Butte Springs	0.55	
07/11/22	07/11/2022 12:00 am	Big Butte Springs	0.55	
07/12/22	07/12/2022 12:00 am	Big Butte Springs	0.56	
07/13/22	07/13/2022 03:00 am	Big Butte Springs	0.55	
07/14/22	07/14/2022 05:00 am	Big Butte Springs	0.55	
07/15/22	07/15/2022 02:00 am	Big Butte Springs	0.55	
07/16/22	07/16/2022 12:00 am	Big Butte Springs	0.55	
07/17/22	07/17/2022 07:00 am	Big Butte Springs	0.54	
07/18/22	07/18/2022 12:00 am	Big Butte Springs	0.54	
07/19/22	07/19/2022 12:00 am	Big Butte Springs	0.54	
07/20/22	07/20/2022 12:00 am	Big Butte Springs	0.54	
07/21/22	07/21/2022 05:00 pm	Big Butte Springs	0.53	
07/22/22	07/22/2022 12:00 am	Big Butte Springs	0.53	
07/23/22	07/23/2022 05:00 am	Big Butte Springs	0.54	
07/24/22	07/24/2022 08:00 pm	Big Butte Springs	0.53	
07/25/22	07/25/2022 12:00 am	Big Butte Springs	0.53	
07/26/22	07/26/2022 06:00 am	Big Butte Springs	0.54	
07/27/22	07/27/2022 12:00 am	Big Butte Springs	0.54	
07/28/22	07/28/2022 05:00 am	Big Butte Springs	0.54	
07/29/22	07/29/2022 12:00 am	Big Butte Springs	0.54	
07/30/22	07/30/2022 12:00 am	Big Butte Springs	0.55	
07/31/22	07/31/2022 03:00 am	Big Butte Springs	0.54	

Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L? Yes NO

If yes, what was the longest time period until the required level was restored? _____ Hours

GWS Serving 3,300 or Fewer		GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to _____ mg/L? <i>Attach those results and submit them</i>	Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	Date continuous monitoring equipment failed: / /	
	If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO <i>Attach grab sample results and submit them with this form.</i>	Date it was returned to service: / /	
Printed Name: Dan Perkins	Title: Plant Supervisor	Operator Certification #: 2339	
Singnature: 	Phone #: (541) 774-2434	OR	
Date: 8/1/2022		Small Groundwater System _____	