

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Groundwater Systems**

System Name: Medford Water Commission

PWS ID#: OR 41-00513

Month/Year: **Nov, 2022**

Entry Point: EP-A, Big Butte Springs

Required Minimum Residual: 0.25 mg/L

Date	Time	Source(s) in use	Lowest free Chlorine residual at entry point to distribution system (mg/L)	Notes
11/01/22	11/01/2022 12:00 am	Big Butte Springs	0.56	
11/02/22	11/02/2022 12:00 am	Big Butte Springs	0.56	
11/03/22	11/03/2022 11:00 pm	Big Butte Springs	0.55	
11/04/22	11/04/2022 12:00 am	Big Butte Springs	0.55	
11/05/22	11/05/2022 01:00 am	Big Butte Springs	0.55	
11/06/22	11/06/2022 12:00 am	Big Butte Springs	0.55	
11/07/22	11/07/2022 12:00 am	Big Butte Springs	0.55	
11/08/22	11/08/2022 12:00 am	Big Butte Springs	0.55	
11/09/22	11/09/2022 03:00 am	Big Butte Springs	0.54	
11/10/22	11/10/2022 11:00 am	Big Butte Springs	0.54	
11/11/22	11/11/2022 05:00 am	Big Butte Springs	0.54	
11/12/22	11/12/2022 09:00 am	Big Butte Springs	0.54	
11/13/22	11/13/2022 12:00 am	Big Butte Springs	0.54	
11/14/22	11/14/2022 12:00 am	Big Butte Springs	0.54	
11/15/22	11/15/2022 12:00 am	Big Butte Springs	0.54	
11/16/22	11/16/2022 12:00 am	Big Butte Springs	0.54	
11/17/22	11/17/2022 12:00 am	Big Butte Springs	0.54	
11/18/22	11/18/2022 07:00 am	Big Butte Springs	0.53	
11/19/22	11/19/2022 12:00 am	Big Butte Springs	0.53	
11/20/22	11/20/2022 12:00 am	Big Butte Springs	0.53	
11/21/22	11/21/2022 12:00 am	Big Butte Springs	0.53	
11/22/22	11/22/2022 12:00 am	Big Butte Springs	0.53	
11/23/22	11/23/2022 12:00 am	Big Butte Springs	0.54	
11/24/22	11/24/2022 01:00 am	Big Butte Springs	0.54	
11/25/22	11/25/2022 12:00 am	Big Butte Springs	0.56	
11/26/22	11/26/2022 12:00 am	Big Butte Springs	0.56	
11/27/22	11/27/2022 09:00 pm	Big Butte Springs	0.56	
11/28/22	11/28/2022 12:00 am	Big Butte Springs	0.56	
11/29/22	11/29/2022 12:00 am	Big Butte Springs	0.57	
11/30/22	11/30/2022 02:00 am	Big Butte Springs	0.58	
		Big Butte Springs		

Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L?  Yes  NO

If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours

GWS Serving 3,300 or Fewer	GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to _____ mg/L?  <i>Attach those results and submit them</i>	Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO <i>Attach grab sample results and submit them with this form.</i>	Date continuous monitoring equipment failed: / /  Date it was returned to service: / /

Printed Name: Dan Perkins	Title: Plant Supervisor	Operator Certification #: 2339  OR Small Groundwater System _____
Singnature: 	Phone #: (541) 774-2434	
Date: 12/1/2022		