

State of Oregon Drinking Water Program
Monthly Disinfection Report for Groundwater Systems

System Name: Medford Water Commission

PWS ID#: OR 41-00513

Month/Year: **Jan, 2025**

Entry Point: EP-A, Big Butte Springs

Required Minimum Residual: 0.25 mg/L

Date	Time	Source(s) in use	Lowest free Chlorine residual at entry point to distribution system (mg/L)	Notes
01/01/25	01/01/2025 04:00 pm	Big Butte Springs	0.54	
01/02/25	01/02/2025 12:00 am	Big Butte Springs	0.54	
01/03/25	01/03/2025 10:00 am	Big Butte Springs	0.55	
01/04/25	01/04/2025 10:00 am	Big Butte Springs	0.54	
01/05/25	01/05/2025 03:00 am	Big Butte Springs	0.55	
01/06/25	01/06/2025 12:00 am	Big Butte Springs	0.55	
01/07/25	01/07/2025 10:00 am	Big Butte Springs	0.55	
01/08/25	01/08/2025 12:00 am	Big Butte Springs	0.55	
01/09/25	01/09/2025 04:00 pm	Big Butte Springs	0.54	
01/10/25	01/10/2025 12:00 am	Big Butte Springs	0.55	
01/11/25	01/11/2025 09:00 am	Big Butte Springs	0.55	
01/12/25	01/12/2025 12:00 am	Big Butte Springs	0.55	
01/13/25	01/13/2025 05:00 pm	Big Butte Springs	0.55	
01/14/25	01/14/2025 12:00 am	Big Butte Springs	0.55	
01/15/25	01/15/2025 08:00 am	Big Butte Springs	0.55	
01/16/25	01/16/2025 12:00 am	Big Butte Springs	0.55	
01/17/25	01/17/2025 03:00 pm	Big Butte Springs	0.55	
01/18/25	01/18/2025 12:00 am	Big Butte Springs	0.55	
01/19/25	01/19/2025 01:00 pm	Big Butte Springs	0.55	
01/20/25	01/20/2025 12:00 am	Big Butte Springs	0.55	
01/21/25	01/21/2025 03:00 am	Big Butte Springs	0.56	
01/22/25	01/22/2025 12:00 am	Big Butte Springs	0.56	
01/23/25	01/23/2025 08:00 am	Big Butte Springs	0.56	
01/24/25	01/24/2025 12:00 am	Big Butte Springs	0.56	
01/25/25	01/25/2025 04:00 pm	Big Butte Springs	0.56	
01/26/25	01/26/2025 12:00 am	Big Butte Springs	0.56	
01/27/25	01/27/2025 01:00 pm	Big Butte Springs	0.56	
01/28/25	01/28/2025 05:00 am	Big Butte Springs	0.55	
01/29/25	01/29/2025 02:00 pm	Big Butte Springs	0.56	
01/30/25	01/30/2025 12:00 am	Big Butte Springs	0.56	
01/31/25	01/31/2025 08:00 am	Big Butte Springs	0.56	

Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L? ☐ Yes ☒ NO

If yes, what was the longest time period until the required level was restored? _____ Hours

GWS Serving 3,300 or Fewer If yes, did you monitor every four hours until the residual returned to _____ mg/L? <i>Attach those results and submit them</i>	GWS Serving More Than 3,300 Did continuous monitoring equipment fail at any time this reporting month? ☐ YES ☒ NO If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? ☐ YES ☐ NO <i>Attach grab sample results and submit them with this form.</i> Date continuous monitoring equipment failed: / / Date it was returned to service: / /
Printed Name: Matt Severloh Signature: <i>Matt Severloh</i> Date: 2/1/2025	Title: Plant Supervisor Phone #: (541) 774-2743
Operator Certification #: 8480 OR Small Groundwater System _____	