

State of Oregon Drinking Water Program
Monthly Disinfection Report for Groundwater Systems

System Name: Medford Water Commission

PWS ID#: OR 41-00513

Month/Year: **Mar, 2025**

Entry Point: EP-A, Big Butte Springs

Required Minimum Residual: 0.25 mg/L

Date	Time	Source(s) in use	Lowest free Chlorine residual at entry point to distribution system (mg/L)	Notes
03/01/25	03/01/2025 12:00 am	Big Butte Springs	0.58	
03/02/25	03/02/2025 10:00 pm	Big Butte Springs	0.58	
03/03/25	03/03/2025 12:00 am	Big Butte Springs	0.58	
03/04/25	03/04/2025 05:00 am	Big Butte Springs	0.59	
03/05/25	03/05/2025 12:00 am	Big Butte Springs	0.58	
03/06/25	03/06/2025 12:00 am	Big Butte Springs	0.60	
03/07/25	03/07/2025 08:00 am	Big Butte Springs	0.59	
03/08/25	03/08/2025 12:00 am	Big Butte Springs	0.59	
03/09/25	03/09/2025 08:00 pm	Big Butte Springs	0.59	
03/10/25	03/10/2025 12:00 am	Big Butte Springs	0.59	
03/11/25	03/11/2025 10:00 pm	Big Butte Springs	0.58	
03/12/25	03/12/2025 12:00 am	Big Butte Springs	0.58	
03/13/25	03/13/2025 03:00 pm	Big Butte Springs	0.59	
03/14/25	03/14/2025 07:00 pm	Big Butte Springs	0.57	
03/15/25	03/15/2025 06:00 pm	Big Butte Springs	0.53	
03/16/25	03/16/2025 12:00 am	Big Butte Springs	0.53	
03/17/25	03/17/2025 10:00 am	Big Butte Springs	0.55	
03/18/25	03/18/2025 12:00 am	Big Butte Springs	0.55	
03/19/25	03/19/2025 12:00 pm	Big Butte Springs	0.54	
03/20/25	03/20/2025 02:00 am	Big Butte Springs	0.54	
03/21/25	03/21/2025 09:00 pm	Big Butte Springs	0.53	
03/22/25	03/22/2025 12:00 am	Big Butte Springs	0.54	
03/23/25	03/23/2025 12:00 am	Big Butte Springs	0.55	
03/24/25	03/24/2025 12:00 am	Big Butte Springs	0.55	
03/25/25	03/25/2025 12:00 am	Big Butte Springs	0.55	
03/26/25	03/26/2025 12:00 am	Big Butte Springs	0.55	
03/27/25	03/27/2025 08:00 am	Big Butte Springs	0.57	
03/28/25	03/28/2025 12:00 am	Big Butte Springs	0.57	
03/29/25	03/29/2025 01:00 pm	Big Butte Springs	0.56	
03/30/25	03/30/2025 12:00 am	Big Butte Springs	0.56	
03/31/25	03/31/2025 11:00 pm	Big Butte Springs	0.59	

Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L? ☐ Yes ☒ NO

If yes, what was the longest time period until the required level was restored? _____ Hours

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L?</p> <p><i>Attach those results and submit them</i></p>	<p style="text-align: center;">GWS Serving More Than 3,300</p> <div style="display: flex; justify-content: space-between;"> <div style="width: 65%;"> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO</p> <p><i>Attach grab sample results and submit them with this form.</i></p> </div> <div style="width: 30%;"> <p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p> </div> </div>
<p>Printed Name: Matt Severloh</p> <p>Singnature: </p> <p>Date: 4/1/2025</p>	<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <p>Title: Plant Supervisor</p> <p>Phone #: (541) 774-2743</p> </div> <div style="width: 50%;"> <p>Operator Certification #: 8480</p> <p style="text-align: center;">OR</p> <p>Small Groundwater System _____</p> </div> </div>