

State of Oregon Drinking Water Program
Monthly Disinfection Report for Groundwater Systems

System Name: Medford Water Commission

PWS ID#: OR 41-00513

Month/Year: **Feb, 2022**


Entry Point: EP-C, Big Butte Springs

Required Minimum Residual: 0.25 mg/L

Date	Time	Source(s) in use	Lowest free Chlorine residual at entry point to distribution system (mg/L)	Notes
02/01/22	02/01/2022 05:00 am	Big Butte Springs	0.51	
02/02/22	02/02/2022 12:00 am	Big Butte Springs	0.53	
02/03/22	02/03/2022 12:00 pm	Big Butte Springs	0.52	
02/04/22	02/04/2022 05:00 am	Big Butte Springs	0.51	
02/05/22	02/05/2022 03:00 am	Big Butte Springs	0.53	
02/06/22	02/06/2022 09:00 pm	Big Butte Springs	0.53	
02/07/22	02/07/2022 12:00 am	Big Butte Springs	0.53	
02/08/22	02/08/2022 10:00 am	Big Butte Springs	0.52	
02/09/22	02/09/2022 12:00 am	Big Butte Springs	0.52	
02/10/22	02/10/2022 02:00 pm	Big Butte Springs	0.53	
02/11/22	02/11/2022 05:00 am	Big Butte Springs	0.52	
02/12/22	02/12/2022 06:00 pm	Big Butte Springs	0.53	
02/13/22	02/13/2022 08:00 am	Big Butte Springs	0.52	
02/14/22	02/14/2022 08:00 am	Big Butte Springs	0.53	
02/15/22	02/15/2022 01:00 am	Big Butte Springs	0.52	
02/16/22	02/16/2022 03:00 pm	Big Butte Springs	0.52	
02/17/22	02/17/2022 12:00 am	Big Butte Springs	0.52	
02/18/22	02/18/2022 06:00 pm	Big Butte Springs	0.52	
02/19/22	02/19/2022 12:00 am	Big Butte Springs	0.52	
02/20/22	02/20/2022 06:00 pm	Big Butte Springs	0.52	
02/21/22	02/21/2022 12:00 am	Big Butte Springs	0.52	
02/22/22	02/22/2022 11:00 pm	Big Butte Springs	0.52	
02/23/22	02/23/2022 03:00 am	Big Butte Springs	0.51	
02/24/22	02/24/2022 08:00 am	Big Butte Springs	0.51	
02/25/22	02/25/2022 07:00 am	Big Butte Springs	0.50	
02/26/22	02/26/2022 10:00 pm	Big Butte Springs	0.51	
02/27/22	02/27/2022 12:00 am	Big Butte Springs	0.51	
02/28/22	02/28/2022 07:00 am	Big Butte Springs	0.50	
		Big Butte Springs		
		Big Butte Springs		
		Big Butte Springs		

Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L? Yes NO

If yes, what was the longest time period until the required level was restored? _____ Hours

GWS Serving 3,300 or Fewer	GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to _____ mg/L? <i>Attach those results and submit them</i>	Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	Date continuous monitoring equipment failed: / /
	If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO <i>Attach grab sample results and submit them with this form.</i>	
Printed Name: Dan Perkins	Title: Plant Supervisor	Operator Certification #: 2339
Singnature: 	Phone #: (541) 774-2434	OR
Date: 3/1/2022		Small Groundwater System _____