

State of Oregon Drinking Water Program

Monthly Disinfection Report for Groundwater Systems

System Name: Medford Water Commission

PWS ID#: OR 41-00513

Month/Year: **Mar, 2022**


Entry Point: EP-C, Big Butte Springs

Required Minimum Residual: 0.25 mg/L

Date	Time	Source(s) in use	Lowest free Chlorine residual at entry point to distribution system (mg/L)	Notes
03/01/22	03/01/2022 01:00 pm	Big Butte Springs	0.51	
03/02/22	03/02/2022 12:00 am	Big Butte Springs	0.51	
03/03/22	03/03/2022 12:00 pm	Big Butte Springs	0.51	
03/04/22	03/04/2022 12:00 am	Big Butte Springs	0.51	
03/05/22	03/05/2022 08:00 am	Big Butte Springs	0.51	
03/06/22	03/06/2022 12:00 am	Big Butte Springs	0.51	
03/07/22	03/07/2022 01:00 pm	Big Butte Springs	0.49	
03/08/22	03/08/2022 02:00 am	Big Butte Springs	0.50	
03/09/22	03/09/2022 06:00 pm	Big Butte Springs	0.50	
03/10/22	03/10/2022 12:00 am	Big Butte Springs	0.50	
03/11/22	03/11/2022 09:00 am	Big Butte Springs	0.51	
03/12/22	03/12/2022 03:00 am	Big Butte Springs	0.50	
03/13/22	03/13/2022 03:00 pm	Big Butte Springs	0.50	
03/14/22	03/14/2022 12:00 am	Big Butte Springs	0.50	
03/15/22	03/15/2022 07:00 am	Big Butte Springs	0.50	
03/16/22	03/16/2022 06:00 am	Big Butte Springs	0.49	
03/17/22	03/17/2022 07:00 pm	Big Butte Springs	0.49	
03/18/22	03/18/2022 12:00 am	Big Butte Springs	0.49	
03/19/22	03/19/2022 05:00 am	Big Butte Springs	0.50	
03/20/22	03/20/2022 12:00 am	Big Butte Springs	0.50	
03/21/22	03/21/2022 10:00 am	Big Butte Springs	0.50	
03/22/22	03/22/2022 04:00 am	Big Butte Springs	0.49	
03/23/22	03/23/2022 07:00 pm	Big Butte Springs	0.49	
03/24/22	03/24/2022 12:00 am	Big Butte Springs	0.49	
03/25/22	03/25/2022 09:00 pm	Big Butte Springs	0.49	
03/26/22	03/26/2022 12:00 am	Big Butte Springs	0.49	
03/27/22	03/27/2022 12:00 am	Big Butte Springs	0.51	
03/28/22	03/28/2022 12:00 am	Big Butte Springs	0.51	
03/29/22	03/29/2022 04:00 pm	Big Butte Springs	0.51	
03/30/22	03/30/2022 12:00 am	Big Butte Springs	0.51	
03/31/22	03/31/2022 05:00 pm	Big Butte Springs	0.55	

Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L? Yes NO

If yes, what was the longest time period until the required level was restored? _____ Hours

GWS Serving 3,300 or Fewer		GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to _____ mg/L? <i>Attach those results and submit them</i>	Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	Date continuous monitoring equipment failed: / /	
	If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO <i>Attach grab sample results and submit them with this form.</i>	Date it was returned to service: / /	
Printed Name: Dan Perkins		Title: Plant Supervisor	Operator Certification #: 2339
Singnature: 		Phone #: (541) 774-2434	OR
Date: 4/1/2022			Small Groundwater System _____