

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Groundwater Systems**

System Name: Medford Water Commission

PWS ID#: OR 41-00513

Month/Year: **Jun, 2022**


Entry Point: EP-C, Big Butte Springs

Required Minimum Residual: 0.25 mg/L

Date	Time	Source(s) in use	Lowest free Chlorine residual at entry point to distribution system (mg/L)	Notes
06/01/22	06/01/2022 04:00 am	Big Butte Springs	0.54	
06/02/22	06/02/2022 12:00 am	Big Butte Springs	0.53	
06/03/22	06/03/2022 09:00 pm	Big Butte Springs	0.52	
06/04/22	06/04/2022 07:00 am	Big Butte Springs	0.51	
06/05/22	06/05/2022 03:00 am	Big Butte Springs	0.55	
06/06/22	06/06/2022 04:00 am	Big Butte Springs	0.54	
06/07/22	06/07/2022 06:00 am	Big Butte Springs	0.55	
06/08/22	06/08/2022 01:00 am	Big Butte Springs	0.54	
06/09/22	06/09/2022 05:00 am	Big Butte Springs	0.55	
06/10/22	06/10/2022 01:00 am	Big Butte Springs	0.55	
06/11/22	06/11/2022 05:00 am	Big Butte Springs	0.56	
06/12/22	06/12/2022 07:00 am	Big Butte Springs	0.56	
06/13/22	06/13/2022 06:00 am	Big Butte Springs	0.54	
06/14/22	06/14/2022 05:00 am	Big Butte Springs	0.56	
06/15/22	06/15/2022 12:00 am	Big Butte Springs	0.55	
06/16/22	06/16/2022 03:00 am	Big Butte Springs	0.56	
06/17/22	06/17/2022 02:00 am	Big Butte Springs	0.55	
06/18/22	06/18/2022 10:00 pm	Big Butte Springs	0.55	
06/19/22	06/19/2022 07:00 am	Big Butte Springs	0.54	
06/20/22	06/20/2022 12:00 pm	Big Butte Springs	0.55	
06/21/22	06/21/2022 01:00 am	Big Butte Springs	0.55	
06/22/22	06/22/2022 07:00 am	Big Butte Springs	0.55	
06/23/22	06/23/2022 04:00 am	Big Butte Springs	0.55	
06/24/22	06/24/2022 05:00 am	Big Butte Springs	0.55	
06/25/22	06/25/2022 07:00 am	Big Butte Springs	0.54	
06/26/22	06/26/2022 04:00 am	Big Butte Springs	0.57	
06/27/22	06/27/2022 12:00 am	Big Butte Springs	0.57	
06/28/22	06/28/2022 12:00 am	Big Butte Springs	0.58	
06/29/22	06/29/2022 05:00 am	Big Butte Springs	0.58	
06/30/22	06/30/2022 09:00 pm	Big Butte Springs	0.57	
		Big Butte Springs		

Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L?  Yes  NO

If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours

GWS Serving 3,300 or Fewer	GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to ____ mg/L?  <i>Attach those results and submit them</i>	Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO <i>Attach grab sample results and submit them with this form.</i>	Date continuous monitoring equipment failed: / /  Date it was returned to service: / /
Printed Name: Dan Perkins	Title: Plant Supervisor	Operator Certification #: 2339
Singnature: 	Phone #: (541) 774-2434	OR
Date: 7/1/2022		Small Groundwater System _____