

State of Oregon Drinking Water Program
Monthly Disinfection Report for Groundwater Systems

System Name: Medford Water Commission

PWS ID#: OR 41-00513

Month/Year: **Aug, 2022**

Entry Point: EP-C, Big Butte Springs

Required Minimum Residual: 0.25 mg/L

Date	Time	Source(s) in use	Lowest free Chlorine residual at entry point to distribution system (mg/L)	Notes
08/01/22	08/01/2022 08:00 am	Big Butte Springs	0.54	
08/02/22	08/02/2022 05:00 am	Big Butte Springs	0.53	
08/03/22	08/03/2022 07:00 am	Big Butte Springs	0.55	
08/04/22	08/04/2022 06:00 pm	Big Butte Springs	0.48	
08/05/22	08/05/2022 02:00 am	Big Butte Springs	0.55	
08/06/22	08/06/2022 04:00 am	Big Butte Springs	0.54	
08/07/22	08/07/2022 09:00 pm	Big Butte Springs	0.55	
08/08/22	08/08/2022 04:00 am	Big Butte Springs	0.54	
08/09/22	08/09/2022 11:00 am	Big Butte Springs	0.54	
08/10/22	08/10/2022 04:00 am	Big Butte Springs	0.54	
08/11/22	08/11/2022 06:00 am	Big Butte Springs	0.54	
08/12/22	08/12/2022 06:00 am	Big Butte Springs	0.53	
08/13/22	08/13/2022 08:00 am	Big Butte Springs	0.53	
08/14/22	08/14/2022 04:00 am	Big Butte Springs	0.53	
08/15/22	08/15/2022 08:00 am	Big Butte Springs	0.53	
08/16/22	08/16/2022 05:00 am	Big Butte Springs	0.53	
08/17/22	08/17/2022 07:00 am	Big Butte Springs	0.53	
08/18/22	08/18/2022 05:00 am	Big Butte Springs	0.53	
08/19/22	08/19/2022 06:00 am	Big Butte Springs	0.53	
08/20/22	08/20/2022 04:00 am	Big Butte Springs	0.52	
08/21/22	08/21/2022 08:00 am	Big Butte Springs	0.52	
08/22/22	08/22/2022 03:00 am	Big Butte Springs	0.52	
08/23/22	08/23/2022 12:00 am	Big Butte Springs	0.53	
08/24/22	08/24/2022 06:00 am	Big Butte Springs	0.52	
08/25/22	08/25/2022 12:00 am	Big Butte Springs	0.52	
08/26/22	08/26/2022 07:00 am	Big Butte Springs	0.52	
08/27/22	08/27/2022 05:00 am	Big Butte Springs	0.51	
08/28/22	08/28/2022 06:00 pm	Big Butte Springs	0.52	
08/29/22	08/29/2022 05:00 am	Big Butte Springs	0.51	
08/30/22	08/30/2022 06:00 am	Big Butte Springs	0.52	
08/31/22	08/31/2022 05:00 am	Big Butte Springs	0.53	

Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L? Yes NO

If yes, what was the longest time period until the required level was restored? _____ Hours

GWS Serving 3,300 or Fewer	GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to ____ mg/L? <i>Attach those results and submit them</i>	Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO <i>Attach grab sample results and submit them with this form.</i>	Date continuous monitoring equipment failed: / / Date it was returned to service: / /

Printed Name: Dan Perkins	Title: Plant Supervisor	Operator Certification #: 2339 OR Small Groundwater System _____
Signature: 	Phone #: (541) 774-2434	
Date: 9/8/2022		