

State of Oregon Drinking Water Program
Monthly Disinfection Report for Groundwater Systems

System Name: Medford Water Commission

PWS ID#: OR 41-00513

Month/Year: **Sep, 2022**


Entry Point: EP-C, Big Butte Springs

Required Minimum Residual: 0.25 mg/L

Date	Time	Source(s) in use	Lowest free Chlorine residual at entry point to distribution system (mg/L)	Notes
09/01/22	09/01/2022 07:00 am	Big Butte Springs	0.54	
09/02/22	09/02/2022 02:00 am	Big Butte Springs	0.53	
09/03/22	09/03/2022 08:00 am	Big Butte Springs	0.53	
09/04/22	09/04/2022 05:00 am	Big Butte Springs	0.52	
09/05/22	09/05/2022 07:00 am	Big Butte Springs	0.53	
09/06/22	09/06/2022 06:00 am	Big Butte Springs	0.52	
09/07/22	09/07/2022 05:00 am	Big Butte Springs	0.53	
09/08/22	09/08/2022 05:00 am	Big Butte Springs	0.52	
09/09/22	09/09/2022 08:00 am	Big Butte Springs	0.52	
09/10/22	09/10/2022 06:00 am	Big Butte Springs	0.51	
09/11/22	09/11/2022 07:00 am	Big Butte Springs	0.52	
09/12/22	09/12/2022 04:00 am	Big Butte Springs	0.51	
09/13/22	09/13/2022 08:00 am	Big Butte Springs	0.51	
09/14/22	09/14/2022 06:00 am	Big Butte Springs	0.51	
09/15/22	09/15/2022 07:00 am	Big Butte Springs	0.51	
09/16/22	09/16/2022 06:00 am	Big Butte Springs	0.50	
09/17/22	09/17/2022 09:00 pm	Big Butte Springs	0.50	
09/18/22	09/18/2022 12:00 am	Big Butte Springs	0.50	
09/19/22	09/19/2022 07:00 am	Big Butte Springs	0.51	
09/20/22	09/20/2022 04:00 am	Big Butte Springs	0.50	
09/21/22	09/21/2022 09:00 pm	Big Butte Springs	0.50	
09/22/22	09/22/2022 12:00 am	Big Butte Springs	0.50	
09/23/22	09/23/2022 04:00 am	Big Butte Springs	0.51	
09/24/22	09/24/2022 03:00 am	Big Butte Springs	0.50	
09/25/22	09/25/2022 06:00 am	Big Butte Springs	0.52	
09/26/22	09/26/2022 03:00 am	Big Butte Springs	0.51	
09/27/22	09/27/2022 04:00 am	Big Butte Springs	0.54	
09/28/22	09/28/2022 03:00 am	Big Butte Springs	0.53	
09/29/22	09/29/2022 03:00 am	Big Butte Springs	0.55	
09/30/22	09/30/2022 04:00 am	Big Butte Springs	0.53	
		Big Butte Springs		

Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L? Yes NO

If yes, what was the longest time period until the required level was restored? _____ Hours

GWS Serving 3,300 or Fewer		GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to ____ mg/L? <i>Attach those results and submit them</i>	Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	Date continuous monitoring equipment failed: / /	
	If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO <i>Attach grab sample results and submit them with this form.</i>	Date it was returned to service: / /	
Printed Name: Dan Perkins		Title: Plant Supervisor	
Singnature: 		Operator Certification #: 2339	
Date: 10/4/2022		OR Small Groundwater System _____	