

State of Oregon Drinking Water Program
Monthly Disinfection Report for Groundwater Systems

System Name: Medford Water Commission

PWS ID#: OR 41-00513

Month/Year: **Jun, 2023**


Entry Point: EP-C, Big Butte Springs

Required Minimum Residual: 0.25 mg/L

Date	Time	Source(s) in use	Lowest free Chlorine residual at entry point to distribution system (mg/L)	Notes
06/01/23	06/01/2023 06:00 am	Big Butte Springs	0.53	
06/02/23	06/02/2023 09:00 pm	Big Butte Springs	0.55	
06/03/23	06/03/2023 04:00 am	Big Butte Springs	0.54	
06/04/23	06/04/2023 09:00 pm	Big Butte Springs	0.55	
06/05/23	06/05/2023 03:00 am	Big Butte Springs	0.54	
06/06/23	06/06/2023 07:00 am	Big Butte Springs	0.56	
06/07/23	06/07/2023 05:00 am	Big Butte Springs	0.54	
06/08/23	06/08/2023 09:00 pm	Big Butte Springs	0.56	
06/09/23	06/09/2023 02:00 am	Big Butte Springs	0.55	
06/10/23	06/10/2023 06:00 am	Big Butte Springs	0.56	
06/11/23	06/11/2023 04:00 am	Big Butte Springs	0.54	
06/12/23	06/12/2023 04:00 am	Big Butte Springs	0.57	
06/13/23	06/13/2023 04:00 am	Big Butte Springs	0.55	
06/14/23	06/14/2023 04:00 am	Big Butte Springs	0.56	
06/15/23	06/15/2023 03:00 am	Big Butte Springs	0.56	
06/16/23	06/16/2023 05:00 am	Big Butte Springs	0.59	
06/17/23	06/17/2023 04:00 am	Big Butte Springs	0.58	
06/18/23	06/18/2023 08:00 am	Big Butte Springs	0.59	
06/19/23	06/19/2023 04:00 am	Big Butte Springs	0.57	
06/20/23	06/20/2023 05:00 am	Big Butte Springs	0.58	
06/21/23	06/21/2023 01:00 am	Big Butte Springs	0.57	
06/22/23	06/22/2023 07:00 am	Big Butte Springs	0.54	
06/23/23	06/23/2023 05:00 am	Big Butte Springs	0.54	
06/24/23	06/24/2023 07:00 am	Big Butte Springs	0.55	
06/25/23	06/25/2023 06:00 am	Big Butte Springs	0.55	
06/26/23	06/26/2023 11:00 am	Big Butte Springs	0.57	
06/27/23	06/27/2023 01:00 am	Big Butte Springs	0.56	
06/28/23	06/28/2023 08:00 am	Big Butte Springs	0.56	
06/29/23	06/29/2023 12:00 am	Big Butte Springs	0.56	
06/30/23	06/30/2023 06:00 am	Big Butte Springs	0.56	
		Big Butte Springs		

Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L? Yes NO

If yes, what was the longest time period until the required level was restored? _____ Hours

GWS Serving 3,300 or Fewer		GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to _____ mg/L? <i>Attach those results and submit them</i>	Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	Date continuous monitoring equipment failed: / /	
	If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO <i>Attach grab sample results and submit them with this form.</i>	Date it was returned to service: / /	
Printed Name: Matt Severloh	Title: Plant Supervisor	Operator Certification #: 8480	
Singnature: 	Phone #: (541) 774-2743	OR	
Date: 7/6/2023		Small Groundwater System _____	