

State of Oregon Drinking Water Program
Monthly Disinfection Report for Groundwater Systems

System Name: Medford Water Commission

PWS ID#: OR 41-00513

Month/Year: **Jan, 2026**

Entry Point: EP-C, Big Butte Springs

Required Minimum Residual: 0.25 mg/L

| Date | Time | Source(s) in use | Lowest free Chlorine residual at entry point to distribution system (mg/L) | Notes |
|----------|---------------------|-------------------|--|-------|
| 01/01/26 | 01/01/2026 12:00 am | Big Butte Springs | 0.57 | |
| 01/02/26 | 01/02/2026 12:00 am | Big Butte Springs | 0.57 | |
| 01/03/26 | 01/03/2026 12:00 am | Big Butte Springs | 0.57 | |
| 01/04/26 | 01/04/2026 12:00 am | Big Butte Springs | 0.57 | |
| 01/05/26 | 01/05/2026 12:00 am | Big Butte Springs | 0.57 | |
| 01/06/26 | 01/06/2026 12:00 am | Big Butte Springs | 0.57 | |
| 01/07/26 | 01/07/2026 12:00 am | Big Butte Springs | 0.57 | |
| 01/08/26 | 01/08/2026 12:00 am | Big Butte Springs | 0.57 | |
| 01/09/26 | 01/09/2026 12:00 am | Big Butte Springs | 0.57 | |
| 01/10/26 | 01/10/2026 12:00 am | Big Butte Springs | 0.57 | |
| 01/11/26 | 01/11/2026 12:00 am | Big Butte Springs | 0.57 | |
| 01/12/26 | 01/12/2026 12:00 am | Big Butte Springs | 0.57 | |
| 01/13/26 | 01/13/2026 09:00 am | Big Butte Springs | 0.50 | |
| 01/14/26 | 01/14/2026 12:00 am | Big Butte Springs | 0.51 | |
| 01/15/26 | 01/15/2026 01:00 am | Big Butte Springs | 0.51 | |
| 01/16/26 | 01/16/2026 11:00 am | Big Butte Springs | 0.50 | |
| 01/17/26 | 01/17/2026 12:00 am | Big Butte Springs | 0.52 | |
| 01/18/26 | 01/18/2026 02:00 am | Big Butte Springs | 0.51 | |
| 01/19/26 | 01/19/2026 05:00 pm | Big Butte Springs | 0.51 | |
| 01/20/26 | 01/20/2026 01:00 am | Big Butte Springs | 0.51 | |
| 01/21/26 | 01/21/2026 02:00 am | Big Butte Springs | 0.52 | |
| 01/22/26 | 01/22/2026 12:00 am | Big Butte Springs | 0.52 | |
| 01/23/26 | 01/23/2026 12:00 am | Big Butte Springs | 0.53 | |
| 01/24/26 | 01/24/2026 12:00 am | Big Butte Springs | 0.53 | |
| 01/25/26 | 01/25/2026 08:00 am | Big Butte Springs | 0.53 | |
| 01/26/26 | 01/26/2026 12:00 am | Big Butte Springs | 0.53 | |
| 01/27/26 | 01/27/2026 08:00 pm | Big Butte Springs | 0.53 | |
| 01/28/26 | 01/28/2026 04:00 am | Big Butte Springs | 0.53 | |
| 01/29/26 | 01/29/2026 12:00 am | Big Butte Springs | 0.54 | |
| 01/30/26 | 01/30/2026 06:00 am | Big Butte Springs | 0.54 | |
| 01/31/26 | 01/31/2026 07:00 am | Big Butte Springs | 0.54 | |

Was the chlorine residual ever less than the required minimum residual of 0.25 mg/L? Yes NO

If yes, what was the longest time period until the required level was restored? _____ Hours

| | | |
|--|--|--|
| GWS Serving 3,300 or Fewer | GWS Serving More Than 3,300 | |
| If yes, did you monitor every four hours until the residual returned to _____ mg/L? <i>Attach those results and submit them</i> | Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> YES <input type="checkbox"/> NO <i>Attach grab sample results and submit them with this form.</i> | Date continuous monitoring equipment failed: / / Date it was returned to service: / / |
| | Printed Name: Matt Severloh Signature: <i>Matt Severloh</i> Date: 2/2/2026 | Title: Plant Supervisor Phone #: (541) 774-2743 |