

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **FERN VALLEY ESTATES INPRV DISTRICT**

PWS ID# **4 1 00514**

Month/Year **July 2021** Entry Point: **RESERVOIR**

Required Minimum Residual **0.20 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:15	Wells 2,3,4,5,and 6	1.0	
2	7:20		1.0	
3	7:55		0.9	
4	7:15		1.0	
5	8:05		0.9	
6	10:00		0.9	
7	8:35		0.9	
8	7:30		1.0	
9	7:35		0.9	
10	7:55		0.9	
11	7:00		0.8	
12	6:50		0.9	
13	7:35		1.1	
14	7:05		1.3	
15	7:40		1.3	
16	7:40		1.0	
17	8:00P		1.5	FF
18	8:00A		1.2	FF
19	7:00		1.0	
20	6:50		1.0	
21	10:10		0.5	
22	6:50		1.0	
23	6:55		1.0	
24	7:20		1.0	
25	8:00		1.0	
26	7:38		1.0	
27	8:05		0.9	
28	7:10		1.1	
29	7:00		1.1	
30	7:50		1.1	
31	11:15		1.0	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: Mark Elias Signature: <i>Mark Elias</i> Date: 8/3/21	Title: Systems Operator Phone #: (541) 840-0612	Operator Certification #: OR Small Groundwater System <input checked="" type="checkbox"/>
--	--	---