

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **FERN VALLEY ESTATES INPRV DISTRICT**

PWS ID# **4 1 00514**

Month/Year **DEC 12021**

Entry Point: **RESERVOIR**

Required Minimum Residual **0.20 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:25	Wells 2,3,4,5,and 6	1.1	
2	7:35		1.1	
3	7:55		1.0	
4	9:35		1.4	
5	7:45		1.1	
6	8:30		1.0	
7	7:55		0.9	
8	7:45		0.9	
9	8:40		0.8	
10	7:55		0.9	
11	8:45		1.0	
12	7:35		0.9	
13	8:05		0.9	
14	8:20		0.9	
15	7:40		1.0	
16	7:50		1.0	
17	7:25		1.0	
18	8:00		0.9	
19	7:45		1.0	
20	7:55		1.1	
21	9:15		1.0	
22	7:45		1.1	
23	9:25		1.2	
24	8:00		1.0	
25	9:45		1.1	
26	8:30		1.0	
27	10:30		1.0	
28	8:10		1.0	
29	7:10		1.0	
30	8:10		0.9	
31	7:25		0.9	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____ / _____ / _____</p> <p>Date it was returned to service: _____ / _____ / _____</p>
--	--	---

Printed Name: Mark Elias	Title: Systems Operator	Operator Certification #:
Signature: <i>Mark Elias</i>	Phone #: (541) 840-0612	OR
Date: DEC 31, 2021		Small Groundwater System <input checked="" type="checkbox"/>