State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name					NS ID# 41 0	0514	
Month/Year July 12072 Entry Point: RESERVOIR Required Minimum Residual 0.20 mg/L						Residual 0.20 mg/L	
Date	Time	Source(s) ir	use	Lowest free chlorine residual at entry point to distribution system (mg/l		Notes	
1	650A	Wells 2,3,4,5,and 6		0.62			
2	715A			2,20			
3	6.20			0.85			
4	6:45	**************************************		0,83			
5	7:40			6,80			
6	7:45			0.91			
7 8	7.35		· · · · · · · · · · · · · · · · · · ·	0.81			
9	4:30			1.01			
10	7:10	****		0.93			
11	6:00			0.85			
12	7:30	· · · · · · · · · · · · · · · · · · ·		0.98			
13	7:55			0.81			
14	7:15			0.77			
15	7:55			0.76			
16	7:35			8.70			
17	8:05			0.60			
18	6:40			0.79			
19	7:50		±0	0.79		e e	
20	6:35			092			
21	7:50			1.07		···	
22	7:20	T		0,96		1	
23	7:45			0.89		Married and write a second district and a district	
24	8:15			0.83			
25 26	7:20			0,78			
27	7:30			0.74			
28	625			0.90			
29	7:15			1.00			
30	7:35			1.17	1. *	٠,٠	
31	8:25		· · · · · · · · · · · · · · · · · · ·	1,51	7	V	
Was the chlorine residual ever less than the required minimum residual of ₺, ३ mg/L? ☐ Yes № No							
If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.							
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300							
If yes, did you monitor every four hours until the residual returned to mg/L			Did continuous monitoring equipment fail at any time treporting month? Yes No			Date continuous monitoring equipment failed:	
as required? Yes No Attach those results and submit them with			If yes, were grab samples collected every four he continuous monitoring equipment was returned t			/ / Date it was returned to	
this form.			required? Yes No Attach grab sample results and submit them with		with this form	service:	
Printed Name: Mark Elias			Title: Systems Operator		Operato	Operator Certification #:	
Signatur	re: <i>O 10</i>	W CCH	Phone #: (541) 840-0612		OR		
Date: Aug Z 9 2022 Small Groundwater System 🖂							

December 19, 2012