

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **FERN VALLEY ESTATES INPRV DISTRICT**

PWS ID# **41 00514**

Month/Year **NOV 2022**

Entry Point: **RESERVOIR**

Required Minimum Residual **0.20 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:20	Wells 2,3,4,5,and 6	0.96	
2	8:00		0.59	
3	7:50		0.82	
4	7:15		0.85	
5	8:05		0.87	
6	7:55		1.12	
7	8:50		1.00	
8	8:45		1.10	
9	7:55		0.94	
10	7:55		0.95	
11	9:05		1.21	
12	7:55		0.94	
13	8:40		0.90	
14	7:55		0.89	
15	8:55		0.86	
16	7:35		0.94	
17	7:10		0.88	
18	7:20		0.84	
19	7:45		0.79	
20	7:30		0.75	
21	9:00		1.00	
22	8:15		1.08	
23	7:35		1.25	
24	10:15		1.18	
25	8:25		1.16	
26	7:45		1.16	
27	7:20		1.05	
28	8:05		1.03	
29	7:55		1.08	
30	8:25		1.04	
31				

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>	

Printed Name: **Mark Elias**

Title: **Systems Operator**

Operator Certification #:

Signature: *Mark Elias*

Phone #: **(541) 840-0612**

OR

Date: **12/1/2022**

Small Groundwater System