

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **FERN VALLEY ESTATES INPRV DISTRICT**

PWS ID# **41 00514**

Month/Year **AUG 1 2025** Entry Point: **RESERVOIR**

Required Minimum Residual **0.20 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	6:30	Wells 2,3,4,5,and 6	0.94	
2	6:35		0.92	
3	7:50		0.82	
4	7:05		0.76	
5	7:20		0.78	
6	8:40		0.73	
7	8:30		0.74	
8	8:10		0.93	
9	8:30		1.01	
10	8:00		1.07	
11	8:40		1.08	
12	7:50		1.06	
13	8:05		1.02	
14	9:00		0.99	
15	8:30		1.08	
16	8:40		1.10	
17	11:15		0.83	
18	9:35		0.98	
19	7:55		0.98	
20	8:40		0.80	
21	8:55		0.77	
22	11:05		0.87	
23	8:00		0.89	
24	9:05		0.99	
25	11:15		1.13	
26	9:52		1.11	
27	9:35pm		1.27	
28	12:30pm		1.26	
29	8:50		1.01	
30	9:50		0.79	
31	1:10p		0.82	

Was the chlorine residual ever less than the required minimum residual of

mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored?
notified by end of next business day.

hours - If > 4 hours, Drinking Water Program to be

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: **Mark Elias**

Title: **Systems Operator**

Operator Certification #:

Signature: *Mark Elias*

Phone #: (541) 840-0612

OR

Date: **1 1 9/2/25**

Small Groundwater System ☒

December 19, 2012