

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name BLUE SPRUCE MOBILE ESTATES PWS ID# 41 00515  
 Month/Year 07/21 Entry Point: EP-A Required Minimum Residual 1.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:42	1, 2, 3	1.5	6-14
2	8:22		1.5	
3	10:05		1.5	
4	6:23		1.5	
5	9:09		1.5	
6	7:41		1.5	
7	10:46		1.5	
8	8:40		1.5	
9	7:22		1.5	
10	4:04		1.5	
11	5:43		1.5	
12	8:48		1.5	
13	6:30		1.5	
14	7:10		1.5	
15	7:15		1.5	
16	7:20		1.5	
17	8:46		1.5	
18	9:02		1.5	
19	10:53		1.5	
20	11:37		1.5	
21	12:01		1.5	
22	8:22		1.5	
23	6:01		1.5	
24	5:48		1.5	
25	7:30		1.5	
26	10:20		1.5	
27	11:05		1.5	
28	6:45		1.5	
29	10:11		1.5	
30	8:09		1.5	
31	7:37		1.5	

Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L?  
 If yes, what was the longest time period until the required level was restored?      hours  Yes  No

**GWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to      mg/L?  
 Yes  No  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  
 Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:     /    /      
 Date it was returned to service:     /    /    

Printed Name: Robert Behnenkamp  
 Signature: [Signature]  
 Date: 07/31/21

Title: MANAGER  
 Phone #: (503) 414-9609

Operator Certification #:       
 OR  
 Small Groundwater System