

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name BLUE SPRUCE MOBILE ESTATES PWS ID# 41 00515

Month/Year 05/24 Entry Point: EP-A Required Minimum Residual 1.2 mg/L

Date	Time	Source(s) in use <u>1, 2, 3</u>	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:20	}	1.4	14
2	10:20		1.4	
3	6:16		1.4	
4	9:20		1.4	
5	10:11		1.4	
6	6:02		1.4	
7	7:37		1.4	
8	8:02		1.4	
9	10:02		1.4	
10	9:40		1.4	
11	8:20		1.4	
12	1:57		1.4	
13	8:20		1.3	
14	6:49		1.3	
15	9:30		1.3	
16	10:20		1.3	
17	9:40		1.3	
18	2:50		1.3	
19	10:55		1.3	
20	7:07		1.3	
21	7:25		1.3	
22	7:29		1.3	
23	7:04		1.3	
24	7:20		1.3	
25	6:57		1.3	
26	9:32		1.3	
27	10:04		1.5	
28	6:22		1.6	
29	8:30		1.5	
30	8:15		1.6	
31	6:20		1.6	

Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L? Yes No
If yes, what was the longest time period until the required level was restored? 1 hours

GWS Serving 3,300 or Fewer
If yes, did you monitor every four hours until the residual returned to mg/L?
 Yes No
Attach those results and submit them with this form.

GWS Serving More Than 3,300
Did continuous monitoring equipment fail at any time this reporting month? Yes No
If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?
 Yes No
Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /
Date it was returned to service: / /

Printed Name: Mary Jo Burgett Title: MANAGER
Signature: Mary Jo Burgett Phone #: (702) 769-3876
Date: 05/31/2024

Operator Certification #:
OR
Small Groundwater System