

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name:	Newberg City of	PWS ID# 41 00557
Month/Year	09/2021	Entry Point: WTP-A
		Required Minimum Chlorine Residual 0.20 mg/L

Date	Time	Sources(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	08:00	Well Field	1.06	
2	08:00	"	0.94	
3	08:00	"	0.82	
4	08:00	"	0.76	
5	08:00	"	0.71	
6	08:00	"	0.48	
7	08:00	"	0.91	
8	08:00	"	1.30	
9	08:00	"	1.30	
10	08:00	"	0.43	
11	08:00	"	0.45	
12	08:00	"	0.85	
13	08:00	"	0.93	
14	08:00	"	0.95	
15	08:00	"	0.98	
16	08:00	"	0.69	
17	08:00	"	0.84	
18	08:00	"	0.81	
19	08:00	"	0.76	
20	08:00	"	0.70	
21	08:00	"	0.75	
22	08:00	"	0.81	
23	08:00	"	0.74	
24	08:00	"	0.87	
25	08:00	"	0.92	
26	08:00	"	0.98	
27	08:00	"	1.01	
28	08:00	"	1.07	
29	08:00	"	1.06	
30	08:00	"	1.21	
31				

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L?  Yes  No  
 If yes, what was the longest period until the required level was restored? \_\_\_\_\_ hours

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>if yes, did you monitor every four hours until the residual returned to _____ mg/L?</p> <p><i>Attach those results and submit them with this form</i></p>	<p><b>GWS Serving More than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>attach grab sample results and submit them with this form.</i></p>	<p>Date continues monitoring equipment failed / /</p> <p>Date it was returned to service: / /</p>
---	---	---

Printed Name: Daniel Wilson Signature: Date: 10/01/2021	Title: Water Treatment Superintendent Phone #: (503) 537-1239	Operator Certification #: 593 OR Small Groundwater System <input type="checkbox"/>
---	--	--