## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name:		Newberg City of		PWS ID# 41 00557		
Month/Year	r	12/2021	Entry Point:	WTP-A	Required	Minimum Chlorine Residual 0.20 mg/L
Date	Time	Sources(	s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1	08:00	Well Field		0.90		
2	08:00	"		0.67		
3	08:00	"		0.67		
4	08:00	n .		0.76		
5	08:00	"		0.81		
6	08:00	"		0.83		
7	08:00	"		0.34		
8	08:00	"		0.37		
9	08:00	"		0.60		
10	08:00	"		0.48		
11	08:00	"		0.70		
12	08:00	"		0.77		
13	08:00	"		1.01		
14	08:00	"		0.77		
15	08:00	"		0.92		
16	08:00	"		0.95		
17	08:00	"		0.45		
18	08:00	"		0.49		
19	08:00	"		1.09		
20	08:00	"		0.94		
21	08:00	"		1.23		
22	08:00	"		0.73		
23	08:00	"		0.62		
24	08:00	"		0.53		
25	08:00	"		0.64		
26	08:00	"		0.69		
27	08:00	"		1.09		
28	08:00	"		0.67		
29	08:00	"		0.64		
30	08:00	"		0.97		
31	08:00	"		0.94		
		al ever less than the request period until the requ			XN	0
		3,300 or Fewer	GWS Serving More than 3,300			
if yes, did you monitor every four hours			Did continuous monitoring equipment fail at any time this			Date continues monitoring
until the residual returned to mg/L?			reporting month? Yes XNo			equipment failed
Attach those results and submit them with this form			If yes, were grab samples collected every four hours until the			
			continuous monitoring equipment was returned to service Yes No attach grab sample results and submit them with this form.			Date it was returned to service:
					m.	<u> </u>
Printed Name: Pavil Snegirev			Title: Senior Operator			Operator Certification #: 593
Signature:			Phone #: (503) 554-6839			OR Small Groundwater System
Date:	01/03/2022	2				, <u> </u>