State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name:		Newberg City of		PWS ID# 41 00557	
Month/Year	r	01/2024	Entry Point:	WTP-A	Required Minimum Chlorine Residual 0.20 mg/L
Date	Time	Sources(Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	08:00	Well Field		0.47	
2	08:00	"		1.05	
3	08:00	ıı .		0.98	
4	08:00	II .		0.85	
5	08:00	II .		0.78	
6	08:00	II .		0.49	
7	08:00	II .		0.74	
8	08:00	II .		0.77	
9	08:00	II .		0.86	
10	08:00	II .		0.87	
11	08:00	ıı .		0.72	
12	08:00	II .		0.58	
13	08:00	"		0.65	
14	08:00	"		0.64	
15	08:00	"		0.71	
16	08:00	"		0.84	
17	08:00	"		0.68	
18	08:00	"		0.67	
19	08:00	"		0.63	
20	08:00	"		0.49	
21	08:00	"		0.76	
22	08:00	"		0.70	
23	08:00	"		0.42	
24	08:00	"		0.70	
25	08:00	"		0.62	
26	08:00	"		0.60	
27	08:00	"		0.61	
28	08:00	"		0.47	
29	08:00	"		0.81	
30	08:00	"		0.91	
31	08:00	"		1.03	
Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes If yes, what was the longest period until the required level was restored? hours					
GWS	Serving 3	3,300 or Fewer		GWS Serving M	ore than 3,300
if yes, did you monitor every four hours until the residual returned to mg/L?			Did continuous mon reporting month?	itoring equipment fail at any time this Yes X No	Date continues monitoring equipment failed / /
Attach those results and submit them with this form			-	mples collected every four hours until ring equipment was returned to service Yes	
			attach grab sample	results and submit them with this for	n.
Printed Nar	me: Daniel	L Wilson	Title: Water	Treatment Superintendent	Operator Certification #: 5076
Signature:		HANTH	Phone #: (50	03) 537-1239	OR Small Groundwater System
Date:	02/01/2024	1			