State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name:		Newberg City of		PWS ID# 41 00557		
Month/Year	r	08/2024	Entry Point:	WTP-A	Require	d Minimum Chlorine Residual 0.20 mg/L
Date	Time	Sources(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1	08:00	Well Field		0.78		
2	08:00	"		1.00		
3	08:00	"		0.99		
4	08:00	II .		1.06		
5	08:00	m		0.91		
6	08:00	II .		0.32		
7	08:00	"		0.38		
8	08:00	"		0.92		
9	08:00	"		0.63		
10	08:00	"		0.83		
11	08:00	"		0.98		
12	08:00	n .		0.87		
13	08:00	"		0.90		
14	08:00	"		0.95		
15	08:00	"		0.92		
16	08:00	"		0.79		
17	08:00	"		0.79		
18	08:00	"		0.93		
19	08:00	"		0.80		
20	08:00	"		0.78		
21	08:00	"		0.67		
22	08:00	"		0.78		
23	08:00	"		0.85		
24	08:00	"		0.93		
25	08:00	"		1.16		
26	08:00	"		1.21		
27	08:00	"		0.91		
28	08:00	"		1.05		
29	08:00	"		1.05		
30	08:00	"		0.67		
31	08:00	"		0.70		
		al ever less than the request period until the requ			X	No
		3,300 or Fewer		GWS Serving M	lore than	3,300
if yes, did you monitor every four hours			Did continuous monitoring equipment fail at any time this			Date continues monitoring
until the residual returned to mg/L?			reporting month?	Yes XNo		equipment failed / /
Attach those results and submit them with this			If yes, were grab sar	mples collected every four hours until	I the	
form			continuous monitoring equipment was returned to service Yes No attach grab sample results and submit them with this form.			Date it was returned to service:
					m.	<u> </u>
Printed Name: Daniel L Wilson			Title: Water Treatment Superintendent			Operator Certification #: 5076
Signature:		HASTA .	Phone #: (503) 537-1239			OR Small Groundwater System
Date: 09/03/2024						