State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name:		Newberg City of		PWS ID# 41 00557			
Month/Yea	r	01/2025	Entry Point:	WTP-A	Required Minimu	m Chlorine Residual 0.20 mg/L	
				Lowest free chlorine			
Date	Time	Sources(s) in use	residual at entry point to		Notes	
				distribution system (mg/L)			
1	08:00	Well Field		1.57			
2	08:00	"		1.48			
3	08:00	"		1.12			
4	08:00	н		0.70			
5	08:00	н		0.96			
6	08:00	н		0.94			
7	08:00	н		0.82			
8	08:00	"		1.04			
9	08:00	"		1.07			
10	08:00	"		1.00			
11	08:00	"		0.71			
12	08:00	"		0.96			
13	08:00	"		0.98			
14	08:00	н		1.03			
15	08:00	н		1.19			
16	08:00	н		1.16			
17	08:00	н		1.06			
18	08:00	"		0.77			
19	08:00	"		0.95			
20	08:00	"		1.08			
20	08:00	11		1.17			
22	08:00	11		1.04			
23	08:00	н		0.95			
23	08:00	н		0.69			
25	08:00	11		0.60			
26	08:00	11		0.70			
20	08:00	11		0.80			
28	08:00	11		0.83			
20	08:00	11		0.55			
30	08:00			0.33			
30	08:00			0.69			
- 31	08.00			0.09			
Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L?							
If yes, what was the longest period until the required level was restored?							
GWS	Serving 3	,300 or Fewer		GWS Serving I	lore than 3,300		
if yes, did you monitor every four hours			Did continuous moni	itoring equipment fail at any time thi	3	Date continues monitoring	
until the residual returned to mg/L?			reporting month?	Yes X No		equipment failed	
		-				/ /	
Attach those results and submit them with this			If yes, were grab sar	nples collected every four hours un	il the		
form			continuous monitor	ring equipment was returned to serv	ice	Date it was returned to	
			TYes No			service:	
						/ /	
			attach grab sample results and submit them with this form.		m.		
Printed Name: Jon Hodgkins			Title: Operations Supervisor		Operator	Certification #: 09290	
Signature:	Jon H	odghins	Phone #: (503) 593-6723			OR	
Signataro.		<u> </u>			Small G	roundwater System	
Date:	02/04/2024						