

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name:	Newberg City of	PWS ID# 41 00557
Month/Year	02/2025	Entry Point: WTP-A
		Required Minimum Chlorine Residual 0.20 mg/L

Date	Time	Sources(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	08:00	Well Field	0.90	
2	08:00	"	1.02	
3	08:00	"	0.81	
4	08:00	"	0.75	
5	08:00	"	0.85	
6	08:00	"	0.61	
7	08:00	"	0.35	
8	08:00	"	1.16	
9	08:00	"	0.98	
10	08:00	"	0.86	
11	08:00	"	0.88	
12	08:00	"	0.54	
13	08:00	"	0.40	
14	08:00	"	0.29	
15	08:00	"	0.68	
16	08:00	"	0.90	
17	08:00	"	1.11	
18	08:00	"	1.17	
19	08:00	"	0.63	
20	08:00	"	0.67	
21	08:00	"	0.77	
22	08:00	"	0.77	
23	08:00	"	1.10	
24	08:00	"	1.14	
25	08:00	"	1.10	
26	08:00	"	0.85	
27	08:00	"	1.02	
28	08:00	"	0.93	

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? ☐ Yes ☒ No
 If yes, what was the longest period until the required level was restored? _____ hours

<p>GWS Serving 3,300 or Fewer</p> <p>if yes, did you monitor every four hours until the residual returned to _____ mg/L?</p> <p><i>Attach those results and submit them with this form</i></p>	<p>GWS Serving More than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>attach grab sample results and submit them with this form.</i></p>
<p>Date continues monitoring equipment failed / /</p> <p>Date it was returned to service: / /</p>	

Printed Name: Jon Hodgkins	Title: Operations Supervisor	Operator Certification #: 09290
Signature: <u>Jon Hodgkins</u>	Phone #: (503) 593-6723	OR

Date: 03/05/2024

Small Groundwater System ☐