## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name:		Newberg City of		PWS ID# 41 00557			
Month/Yea	r	04/2025	Entry Point:		Requir	red Minimum Chlorine Residual 0.20 mg/L	
_				Lowest free chlorine		••	
Date	Time	Sources(s	s) in use	residual at entry point to		Notes	
				distribution system (mg/L)			
1	08:00	Well Field		0.90			
2	08:00	"		0.94			
3	08:00	II .		0.84			
4	08:00	"		0.72			
5	08:00	"		0.45			
6	08:00	"		0.54			
7	08:00	"		0.81			
8	08:00	"		1.08			
9	08:00	"		1.28			
10	08:00	"		1.20			
11	08:00	"		0.67			
12	08:00	"		0.74			
13	08:00	"		0.67			
14	08:00	n n		0.65			
15	08:00	"		0.69			
16	08:00	"		1.04			
17	08:00	"		1.00			
18	08:00	"		0.76			
19	08:00	"		1.09			
20	08:00	"		1.06			
21	08:00	"		1.03			
22	08:00	"		1.55			
23	08:00	"		1.37			
24	08:00	"		1.01			
25	08:00	"		0.95			
26	08:00	"		0.83			
27	08:00	"		0.87			
28	08:00			0.90			
29	08:00			0.93			
30	08:00			0.68			
Was the chlo	orine residua	l ever less than the requ	uired minimum residu	al of 0.20 mg/L?	Х	No	
If yes, what was the longest period until the required level was restored? hours							
GWS Serving 3,300 or Fewer			GWS Serving More than 3,300				
if yes, did you monitor every four hours			Did continuous monitoring equipment fail at any time this			Date continues monitoring	
until the residual returned to mg/L?			reporting month? Yes X No			equipment failed / /	
Attach those results and submit them with this			If ves, were grab sar	nples collected every four hours unti	I the	·	
form				ring equipment was returned to servi		Date it was returned to	
				Yes No	-	service:	
						/ /	
			attach grab sample results and submit them with this form.				
Printed Name: Jon Hodgkins			Title: Operations Supervisor			Operator Certification #: 09290	
			Phone #: (503) 593-6723			OR	
Signature:		(1000)		JOJ JEJ-UI ZJ		Small Groundwater System	
Date:	Date: 05/02/2025						