State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name:		Newberg City of	PWS ID# 41 00557			
Month/Yea	r	05/2025	Entry Point:	WTP-A	Required	d Minimum Chlorine Residual 0.20 mg/L
				Lowest free chlorine		
Date	Time	Sources(s	s) in use	residual at entry point to		Notes
				distribution system (mg/L)		
1	08:00	Well Field		0.42		
2	08:00	"		0.34		
3	08:00	"		0.71		
4	08:00	"		1.27		
5	08:00	н		1.21		
6	08:00	"		1.00		
7	08:00	"		0.81		
8	08:00	п		0.77		
9	08:00	"		0.48		
10	08:00	н		0.67		
11	08:00	н		0.69		
12	08:00	н		0.72		
13	08:00	"		1.03		
14	08:00	н		1.32		
15	08:00	"		1.08		
16	08:00	н		0.94		
17	08:00	11		0.94		
18	08:00	"		1.14		
19	08:00	"		1.14		
		"				
20	08:00			0.68		
21	08:00			0.70		
22	08:00			0.95		
23	08:00	"		0.68		
24	08:00			1.07		
25	08:00	"		1.02		
26	08:00	"		0.91		
27	08:00	"		0.91		
28	08:00	"		0.99		
29	08:00	"		0.91		
30	08:00	"		0.95		
31	08:00	н		0.73		
Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L?						
If yes, what was the longest period until the required level was restored? hours						
GWS	S Serving 3	,300 or Fewer		GWS Serving M		3,300
if yes, did you monitor every four hours				itoring equipment fail at any time this	;	Date continues monitoring
until the residual returned to mg/L?			reporting month? Yes XNo			equipment failed / /
Attach those results and submit them with this			If yes, were grab sar	nples collected every four hours until	I the	
form			continuous monitoring equipment was returned to service			Date it was returned to
						service: / /
			attach grab sample results and submit them with this form.		<i>m</i>	
Printed Name: Jon Hodgkins			Title: Operations Supervisor			Operator Certification #: 09290
Signature: HodgkinVS			Phone #: (503) 593-6723			OR
Date: 06/02/2025						Small Groundwater System