

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name:	Newberg City of	PWS ID# 41 00557
Month/Year	06/2025	Entry Point: WTP-A
		Required Minimum Chlorine Residual 0.20 mg/L

Date	Time	Sources(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	08:00	Well Field	0.86	
2	08:00	"	0.69	
3	08:00	"	0.66	
4	08:00	"	0.94	
5	08:00	"	0.84	
6	08:00	"	0.91	
7	08:00	"	0.85	
8	08:00	"	0.87	
9	08:00	"	1.01	
10	08:00	"	0.81	
11	08:00	"	0.82	
12	08:00	"	0.77	
13	08:00	"	0.77	
14	08:00	"	0.69	
15	08:00	"	0.50	
16	08:00	"	0.95	
17	08:00	"	0.70	
18	08:00	"	0.73	
19	08:00	"	0.41	
20	08:00	"	1.38	
21	08:00	"	0.88	
22	08:00	"	0.59	
23	08:00	"	0.50	
24	08:00	"	0.73	
25	08:00	"	0.69	
26	08:00	"	0.66	
27	08:00	"	0.55	
28	08:00	"	0.58	
29	08:00	"	1.49	
30	08:00	"	1.52	

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? ☐ Yes ☒ No
 If yes, what was the longest period until the required level was restored? _____ hours

GWS Serving 3,300 or Fewer if yes, did you monitor every four hours until the residual returned to _____ mg/L? <i>Attach those results and submit them with this form</i>	GWS Serving More than 3,300 <div style="display: flex; justify-content: space-between;"> <div style="width: 65%;"> Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service <input type="checkbox"/> Yes <input type="checkbox"/> No <i>attach grab sample results and submit them with this form.</i> </div> <div style="width: 30%; border-left: 1px solid black; padding-left: 10px;"> Date continues monitoring equipment failed / / Date it was returned to service: / / </div> </div>
--	---

Printed Name: Jon Hodgkins Signature: <u>Jon Hodgkins</u> Date: 07/04/2025	Title: Operations Supervisor Phone #: (503) 593-6723	Operator Certification #: 09290 OR Small Groundwater System <input type="checkbox"/>
--	---	--